

FRANKLIN COUNTY HEALTH DEPARTMENT

PERMIT NUMBER: 142886	DATE: 20010705	OWNER: 20724	SIZE: .98A
APPLICANT: ROBINSON ALBERT E 2167 MINERAL SPRINGS RD BOYDTON VA 23917 TELEPHONE: 981-0402		ROBINSON ALBERT E 2167 MINERAL SPRINGS RD BOYDTON VA 23917	
COMMENT: SFD		DESCRIPTION: 5 YEAR ☒	LIFETIME: ☐
LOCATION / DIRECTIONS: FORREST & HAWKINS #26 On Stillwood Dr. Off US 1 South across from Holdens			
FEE: 175.00		SIGNATURE OR OWNER OR AUTHORIZED AGENT: B-B-Q	

THE ABOVE SIGNATURE INDICATES THAT I HAVE READ, UNDERSTAND, AND AGREE WITH ALL PROVISIONS AND INFORMATION AS OUTLINED ON THE BACK SIDE OF THIS FORM


TOPO = P	TEXTURE = P	STRUCTURE = P	DEPTH = P
R. HOR = S	SOIL. WET = S	AVAIL. SP = S	OTHER = S
MINRL = S	OVERALL = P	LTAR = .40	
#BEDRHS = 3	GPD = 360	DISPOSAL = N	TYPE. SYS = C
SZ. TANK = 900	SZ. CHAMB = 0000	NITRIFI = 300X3	TYPE. WAT = P
SITE. LOC = 9.005	MAX TRENCH DEP = 24"	TYP. FAC = SFD	

REMARKS: RUN DRAIN LINES WITH CONTOUR Stay 100' from well, 10' from property lines, 5' from foundation.

CONTRACTOR: James Madden
TANK MANUF: GCP-900 gal
MANUF DATE: 2-9-01

Must use innovative system for a total of 225'

Layout changed after meeting with septic contractor which flagged lines on contour for gravity fed system. off 7/5/01



IMPROVEMENT PERMIT DATE: 20000807

ENV HEALTH SPEC: DF

CONSTRUCTION PERMIT DATE: 20000807

ENV HEALTH SPEC: DF

OPERATION PERMIT DATE: 10-23-01

ENV HEALTH SPEC: Andy Smith, R.