

FRANKLIN COUNTY HEALTH DEPARTMENT

PERMIT NUMBER: 16018C CONST IMPROVE PERMIT	DATE: 20011128	1853-67-4271	SIZE: 0.990A
APPLICANT: SUNNER CONSTRUCTION 1265 FLAT ROCK CHURCH RD LOUISBURG NC 27349		OWNER: DOWDY MARK E & TONI	
TELEPHONE: 556-4481			
COMMENT: SFD	DESCRIPTION: 5 YEAR ☒		LIFETIME: ☐
LOCATION / DIRECTIONS: FLEMING FOREST #48 - 30 WINCHESTER CT YNE			
FEE: 175.00	SIGNATURE OF OWNER OR AUTHORIZED AGENT:		
THE ABOVE SIGNATURE INDICATES THAT I HAVE READ, UNDERSTAND, AND AGREE WITH ALL PROVISIONS AND INFORMATION AS OUTLINED ON THE BACK SIDE OF THIS FORM			
TOPSO <u>PS</u>	TEXTURE <u>PS</u>	STRUCTURE <u>PS</u>	DEPTH <u>PS</u>
R. HOR <u>PS</u>	SOIL. WET <u>\$</u>	AVAIL. SP <u>PS</u>	OTHER
MINRL <u>PS</u>	OVERALL <u>PS</u>	LTAR <u>0.3</u>	
#BEDRMS <u>3</u>	GPD <u>360</u>	DISPOSAL	TYPE. SYS <u>Innov</u>
SZ. TANK <u>1000gal</u>	SZ. CHANB	NITRIFI <u>3'x360'</u>	TYPE. WAT <u>PS</u>
SITE. LOC	MAX TRENCH DEP <u>24"</u>	TYP. FAC <u>SFD</u>	
REMARKS: <u>*Drawing Not to Scale</u>			
* Permit Calls for Use of Innovative System CONTRACTOR: <u>Triangle Pump & Tank</u> TANK MANUF: <u>Ellis 1000gal</u> MANUF DATE: <u>2-22-02</u> * Install Lines along Contour * Install in Dry Conditions * DO NOT PARK or Drive over System Area			
IMPROVEMENT PERMIT DATE: <u>11/30/01</u>		ENV HEALTH SPEC: <u>Andy Smith</u>	
CONSTRUCTION AUTHORIZATION DATE: <u>11/30/01</u>		ENV HEALTH SPEC: <u>Andy Smith</u>	
OPERATION PERMIT DATE: <u>4/29/02</u>		ENV HEALTH SPEC: <u>Andy Smith</u>	