

633

GRANVILLE-VANCE HEALTH DEPARTMENT—Sewage Disposal Record

Owner or Contractor John Wooten Date 10-26-94 S.R. No. 1705
Location/Address Old Franklin Rd - Franklin, NC
Subdivision/Mobile Home Park Name Evans Ridge Lot Size 1A+
Lot No. 11

New System ☒ Repair _____
House ☒ Mobile Home _____ Business _____
No. Bedrooms 3 No. People 2 No. Toilets _____
Water Supply: Private ☒ Approved _____
Semi-Public _____ Unapproved _____
Public _____ None _____

Nitrification System:

Tank Size 900 gal.
Distribution Box 40 No. Lines 3
Nitrification Field 300' - 900' Sq. Ft.
Lines: 1 2 3 4 5 6
Width 3' 3' 3' _____ _____ _____
Length 53/58 65/45 20/40 _____ _____ _____
Grade 3/4" 3" 1/2" 6" 4" 1 1/2" _____ _____ _____
Stone Depth 12" 12" 12" _____ _____ _____

Layout to be followed by installer:

Improvements Permit By Jama C. Parrott Installer J. C. High-Water Co
Certificate of Completion By Jama C. Parrott Date of Inspection 12-22-94

* Construction must comply with all other applicable state and local regulations, but the permit is not a guarantee that the system will not malfunction and the Granville-Vance Health District will not be held responsible for a malfunctioning system.

NOTE: Make sketch of installation showing location of house, septic tanks, privies, water supplies on adjacent property, etc. Write in measurements in order that installations may be located at later date.

