

PERMIT NUMBER

GRANVILLE-VANCE DISTRICT HEALTH DEPARTMENT IMPROVEMENT AND OPERATION PERMITS

COUNTY:	TAX NO.	TYPE OF ESTABLISHMENTS			*THIS PERMIT SHALL BE ACCOMPANIED BY A LAYOUT SHOWN ON A PLAT, INCLUDING SYSTEM REQUIREMENTS.
Granville	SR. NO.	RESIDENCE ☒ BUSINESS ☐ OTHER ☐	NUMBER OF BEDROOMS: 4	NUMBER OF OCCUPANTS: 8 max	
APPLICANT: WYNN CONST.		WATER SUPPLY: Private	WELL ☒ PUBLIC ☐	OTHER ☐	
APPLICANT'S NAME & ADDRESS: 2550 CATHOL DR. STE. 105 COLUMBUS, OH		TYPE OF WASTEWATER SYSTEM	INITIAL INSTALLATION	REPAIR	*THIS IMPROVEMENT PERMIT IS SUBJECT TO REVOCATION IF THE INTENDED USES CHANGE FROM THOSE SHOWN ON THE IMPROVEMENT PERMIT. CHANGES SHALL REQUIRE HEALTH DEPARTMENT APPROVAL.
PROPERTY ADDRESS/LOCATION: 1306 SOUTHWOOD DR.		DESIGN FLOW:	480 GPD	Same	
SUBDIVISION: NEW FOREST		LTAR:	23 GPD / FT ²		
LOT NUMBER: 110		ABSORPTION AREA:	1200 FT ²		
REFERENCE SKETCH (SEE PLAT FOR DETAILS)		TRENCH WIDTH:	3'		
* FOLLOW SOIL SCIENTIST LAYOUT (PLANNED IN FIELDS) * MAINTAIN ALL SETBACKS (W/ NEIGHBORING LOTS TOO) * DO NOT INSTALL/CALL FOR INSPECTION IN WET CONDITIONS * RISE ON TANK		TRENCH DEPTH:	22-24"		
		TRENCH SPACING:	9'-0"		
		TOTAL TRENCH LENGTH:	405' ACCEPTED		
		NUMBER OF TRENCHES:	(3) 135' LINES		
		GRAVEL DEPTH:	ACCEPTED		
		TANK SIZE:	1000 GALLONS		
		PUMP TANK SIZE:	-		
		DISTRIBUTION DEVICE:	"D" BOX		PERMIT VALID FOR: 5 YEARS ☒ YES ☐ NO
					NO EXPIRATION YES ☒ NO ☐

IMPROVEMENT PERMIT

DATE: 1/19/18

FOR: WYNN CONST.

ISSUED BY: [Signature]

CONSTRUCTION AUTHORIZATION FOR IMPROVEMENT PERMIT# 9270

Unless otherwise indicated, the same conditions above apply regarding system type, layout, location and installation requirements.
(The wastewater system cannot be installed until authorization is signed)

Comments: CONTRADICTORY TO RESOLUTION # 2012-001

Date: 1/19/18

Environmental Health Specialist: [Signature]

Construction Authorization Addendum ☒ Yes ☐ No

OPERATION PERMIT

DATE:

SYSTEM INSTALLED BY:

ISSUED BY:

PERFORMANCE, MONITORING, MAINTENANCE AND OPERATION
AS REQUIRED BY RULE .1961

Granville County Health Department
Environmental Health

Pin _____

Permit Number 9290

☒ Improvement Permit

☒ Construction Authorization

Site Sketch

WYNN. CONST.

Applicants Name

Will Bullock

Authorized State Agent

NEW FOREST 110 / 1306 SOURWOOD DR.

Subdivision - Section - Lot

1/19/18

Date

System components represent approximate contours only. The contractor must flag the system prior to beginning the installation to insure that proper grade is maintained.

