



## IMPROVEMENT PERMIT

Franklin County Health Department  
107 Industrial Drive  
Louisburg, NC 27549  
Phone:

### For Office Use Only

\*CDP File Number 459292 - 1  
County ID Number: \_\_\_\_\_  
Evaluated For: NEW

PERMIT VALID UNTIL: 09/11/2030

**\*NOTE TO INSPECTIONS DIVISION:** Building Permits cannot be issued with this Improvement Permit.

Applicant: Bobby Sumner

Address: PO Box 1011

City: Youngsville

State/Zip: NC 27596

Phone #: home: (919) 422-5713

Property Owner: BC Sumner Investments LLC

Address: PO Box 1011

City: Youngsville

State/Zip: NC. 27596

Phone #: home: (919) 422-5713

### Property Location & Site Information

Address: 55 White Deer Lane Youngsville, Subdivision: Block/Phase: NEW Lot: 13  
NC 27596

### Directions

Road #: 55 White Deer Lane

Structure: SINGLE FAMILY

# of Bedrooms: 5

# of People: 10

\*Water Supply: N/A

### System Specifications

#### Initial System

Usable Soil Depth: 48

Design Flow: 600

Soil Application Rate: 0.3000

\*System Classification/Description:

\*Proposed System:  
CONVENTIONAL

Minimum Trench Depth: \_\_\_\_\_ Inches

Maximum Trench Depth: 30 Inches

Septic Tank: 1250 Gallons

Pump Required ☐ Yes ☒ No ☐ May Be Required

Pump Tank: \_\_\_\_\_ Gallons

Repair System Required: ☒ Yes ☐ No ☐ No, but has Available Space

### Repair System

Usable Soil Depth: 48

Soil Application Rate: 0.300

\*System Classification/Description:

\*Proposed System: CONVENTIONAL

Minimum Trench Depth: \_\_\_\_\_ Inches

Maximum Trench: Depth: 30 Inches

Pump Required: ☐ Yes ☒ No ☐ May Be Required

Pump Tank: \_\_\_\_\_ Gallons

No grading or construction activity is allowed in areas designated for system and repair without approval of Health Department.

### \*Site Modifications

The issuance of this permit by the Health Department in no way guarantees the issuance of other permits. The permit holder is responsible for checking with appropriate governing bodies in meeting their requirements.

### \*Permit Conditions

The Department and Local Health Department may impose conditions on the insurance and may revoke the permits for failure of the system to satisfy the conditions, the rules, or this article. This permit is subject to revocation if the site plan, plat, or intended use changes (NCGS 130A-335(f)). The person owning or controlling the system location, installing, operation, maintenance, monitoring, reporting, and repair (per rule .0301(a)).

Authorized State Agent: Wood, Jeffrey Date of Issue: 09/11/2025

Total Time: (HH:MM)

☐ Hand Drawing      ☐ Import Drawing      **\*\*Site Plan/Drawing attached.\*\***             :



## Construction Authorization

Franklin County Health Department  
107 Industrial Drive  
Louisburg, NC 27549  
Phone: \_\_\_\_\_

### For Office Use Only

\*CDP File Number: 459292 - 1  
County ID Number: \_\_\_\_\_  
Evaluated For: NEW

PERMIT VALID UNTIL: 09/11/2030

☐ Open Pump System Sheet

Applicant: Bobby Sumner  
Address: PO Box 1011  
City: Youngsville  
State/Zip: NC 27596  
Phone #: home: (919) 422-5713

Property Owner: BC Sumner Investments LLC  
Address: PO Box 1011  
City: Youngsville  
State/Zip: NC. 27596  
Phone #: home: (919) 422-5713

### Property Location & Site Information

Address/Road #: 55 White Deer Lane Subdivision: \_\_\_\_\_ Phase: NEW Lot: 13  
Youngsville, NC 27596  
Directions:  
Structure: SINGLE FAMILY 55 White Deer Lane  
# of Bedrooms: 5  
# of People: 10  
\*Water Supply: \_\_\_\_\_

### System Specifications

Usable Soil Depth: 48 Minimum Trench Depth: \_\_\_\_\_ Inches  
Design Flow: 600 Maximum Trench Depth: 30 Inches  
Soil Application Rate: 0.3000 Minimum Soil Cover: \_\_\_\_\_ Inches  
\*System Classification/Description: \_\_\_\_\_ Maximum Soil Cover: \_\_\_\_\_ Inches  
\*Proposed System: CONVENTIONAL \*Distribution Type: GRAVITY - PARALLEL (eq. d-box)  
Nitrification Field: \_\_\_\_\_ Sq. ft. Septic Tank: 1,250 Gallons  
No. Drain Lines: \_\_\_\_\_ Pump Required: ☐ Yes ☒ No ☐ May Be Required  
Total Trench Length: 670 ft. ☐ Inches O.C. Pump Tank: \_\_\_\_\_ Gallons  
Trench Spacing: \_\_\_\_\_ - \_\_\_\_\_ ☐ Feet O.C. Grease Trap: \_\_\_\_\_ Gallons  
Trench Width: \_\_\_\_\_ - \_\_\_\_\_ ☐ Inches  
Aggregate Depth: \_\_\_\_\_ inches ☐ Feet  
Septic Tank Installer: \_\_\_\_\_  
Grade Level Required: ☐ I ☐ II ☐ III ☐ IV

The issuance of this permit by the Health Department in no way guarantees the issuance of other permits. The permit holder is responsible for checking with appropriate governing bodies in meeting their requirements.

### \*Permit Conditions:

The Authorization for Wastewater System Construction shall be valid for a period equal to the period of validity of the Improvement Permit and may be issued at the same time the Improvement Permit issued (NCGS 130A-336(b)). If the installation has not been completed during the period of validity of the Construction Permit, the information submitted in the application for a permit or Construction Authorization shall become invalid, and may be suspended or revoked (.0204(k)(1)). The person owning or controlling the system shall be responsible for assuring compliance with the laws, rules, and permit conditions regarding system location, installation, operation, maintenance, monitoring, reporting and repair (per rule .0301((a))).

Authorized State Agent: Wood, Jeffrey Date of Issue: 09/11/2025

☐ Hand Drawing ☐ Import Drawing

**\*\*Site Plan/Drawing attached.\*\***

Total Time : (HH:MM) \_\_\_\_\_



## Well Construction Permit

Franklin County Health Department  
107 Industrial Drive  
Louisburg NC, 27549  
Phone:

### For Office Use Only

\*CDP File Number 459292

PIN Number: \_\_\_\_\_

Tax Lot #: 13 Tax Block #: 051321

Evaluated For: SINGLE FAMILY \ WELL

PERMIT VALID UNTIL: 09/11/2030

Property Owner: BC Sumner Investments LLC

Address: PO Box 1011

City: Youngsville

State/Zip: NC / 27596

Phone #: H: (919) 422-5713

Applicant: Bobby Sumner

Address: PO Box 1011

City: Youngsville

State/Zip: NC / 27596

Phone #: H: (919) 422-5713

### Property Location & Site Information

Address/Road #: \_\_\_\_\_ Subdivision: \_\_\_\_\_ Phase: \_\_\_\_\_ Lot: 13

55 White Deer Lane

Youngsville NC, 27596

\*Proposed use of Well: SINGLE FAMILY

If Other: \_\_\_\_\_

Applicant Email: \_\_\_\_\_

Owner Email: \_\_\_\_\_

**Directions:** 55 White Deer Lane

### Well Contractor Information

Drilling Contractor: \_\_\_\_\_

Driller Registration: \_\_\_\_\_

### Permit Conditions

\*Permit Conditions

Well location, construction and protection must meet all state and local regulations and must be inspected and approved by an authorized representative of the Local Health Department. The permit may be revoked at any time for failure to comply with existing regulations. The siting of approved well construction area(s) by the Health Department is to provide protection from the known possible sources of contamination. The approved well area(s) may not be changed without permission from an authorized representative of the Local Health Department. Issuance of this well permit does not guarantee water quality or adequate water production from the well once it is installed or repaired.

\*Issued By: Wood, Jeffrey

Authorized State Agent: \_\_\_\_\_

Owner/Applicant: \_\_\_\_\_

\*Date of Issue: 09/11/2025



Hand Drawing



Import Drawing

**\*\*Site Plan/Drawing attached.\*\***



File # 459292 PIN# \_\_\_\_\_

Property Address: 55 White Deer Ln

Applicant or Owner Name: Bobby Samner

## Environmental Health Septic/Well Permit Diagram

Building permits cannot be issued nor should construction begin without Construction Authorization issuance.

☒ Septic Improvement Permit ☒ Septic Construction Authorization (CA) ☒ CA Reissue\*\* ☒ As Built  
☒ Well Construction Authorization ☒ Additional Diagram/Specifications Attached

Diagram Date\*\*: 9/9/25 EHS: [Signature]

\*\*Any previously dated CA diagram is revoked and/or invalid. Confirm this is the valid diagram for the site before beginning any construction.

Installation/grouting inspections may be scheduled the day before, or, the day of installation until 9am by contacting the Environmental Health office at 919 496 8100. A revisit fee may apply if installation is not ready for inspection at the time requested. Septic Operations Permits will be issued after installation is approved, all permit conditions are met, and any outstanding fees are paid. Well Certificate of Completion will be issued after well head approval, all permit conditions are met, and any outstanding fees are paid.

Septic Tank 1250 or larger Pump Tank — Drainfield 3x670' Type System C Max Trench Depth 30"

Septic Contractor \_\_\_\_\_ Septic/Pump tank dates \_\_\_\_\_ Pump Fee Paid \_\_\_\_\_

Well Contractor \_\_\_\_\_ Well Head Date: \_\_\_\_\_ Pump Final: \_\_\_\_\_ N/A (circle)

670' gravel or 500' Accepted drainline

