



Construction Authorization

Franklin County Health Department
107 Industrial Drive
Louisburg, NC 27549
Phone: _____

For Office Use Only

*CDP File Number: 399299 - 1
County ID Number: _____
Evaluated For: NEW

PERMIT VALID UNTIL: 09/11/2028

☐ Open Pump System Sheet

Applicant: EASTWOOD HOMES OF RALEIGH LLC
Address: 7101 CREEDMOOR RD
City: RALEIGH
State/Zip: NC 27613
Phone #: _____

Property Owner: EASTWOOD HOMES OF RALEIGH LLC
Address: 7101 CREEDMOOR RD
City: RALEIGH
State/Zip: NC. 27613
Phone #: _____

Property Location & Site Information

Address/Road #: 165 IRONWOOD BLVD Subdivision: GREEN HAVEN Phase: NEW Lot: 46
YOUNGSVILLE, NC 27596
Directions: _____
Structure: SINGLE FAMILY 165 IRONWOOD BLVD
of Bedrooms: 4
of People: 8
*Water Supply: _____

System Specifications

*Site Classification: Provisionally Suitable Minimum Trench Depth: _____ Inches
Design Flow: 480 Maximum Trench Depth: 26 Inches
Soil Application Rate: 0.3000 Minimum Soil Cover: _____ Inches
*System Classification/Description: TYPE II A. CONV SYSTEM (SINGLE-FAMILY OR 480 GPD OR LESS) Maximum Soil Cover: _____ Inches
*Proposed System: 25% REDUCTION *Distribution Type: GRAVITY - SERIAL
Nitrification Field: _____ Sq. ft. Septic Tank: 1,000 Gallons
No. Drain Lines: 4 Pump Required: ☐ Yes ☒ No ☐ May Be Required
Total Trench Length: 400 ft. ☐ Inches O.C. Pump Tank: _____ Gallons
☒ Feet O.C. Grease Trap: _____ Gallons
Trench Spacing: _____ - 9 ☐ Inches
Trench Width: _____ - 3 ☒ Feet
Aggregate Depth: _____ inches Septic Tank Installer
Grade Level Required: ☐ I ☐ II ☐ III ☐ IV

The issuance of this permit by the Health Department in no way guarantees the issuance of other permits. The permit holder is responsible for checking with appropriate governing bodies in meeting their requirements.

*Permit Conditions:

Please install septic system in accordance with attached design sheet(s) submitted by CCSC. Respect all setbacks.

The Authorization for Wastewater System Construction shall be valid for a period equal to the period of validity of the Improvement Permit and may be issued at the same time the Improvement Permit issued (NCGS 130A-336(b)). If the installation has not been completed during the period of validity of the Construction Permit, the information submitted in the application for a permit or Construction Authorization shall become invalid, and may be suspended or revoked (.1937(g)). The person owning or controlling the system shall be responsible for assuring compliance with the laws, rules, and permit conditions regarding system location, installation, operation, maintenance, monitoring, reporting

Authorized State Agent: Jones, Lori Date of Issue: 09/11/2023

☐ Hand Drawing

☒ Import Drawing

****Site Plan/Drawing attached.****

Total Time : (HH:MM) _____



IMPROVEMENT PERMIT

Franklin County Health Department
107 Industrial Drive
Louisburg, NC 27549
Phone:

For Office Use Only

*CDP File Number 399299 - 1
County ID Number:
Evaluated For: NEW

PERMIT VALID UNTIL: 09/11/2028

***NOTE TO INSPECTIONS DIVISION:** Building Permits cannot be issued with this Improvement Permit.

Applicant: EASTWOOD HOMES OF RALEIGH LLC
Address: 7101 CREEDMOOR RD
City: RALEIGH
State/Zip: NC 27613
Phone #:

Property Owner: EASTWOOD HOMES OF RALEIGH LLC
Address: 7101 CREEDMOOR RD
City: RALEIGH
State/Zip: NC. 27613
Phone #:

Property Location & Site Information

Address: 165 IRONWOOD BLVD
YOUNGSVILLE, NC 27596
Subdivision: GREEN HAVEN
Block/Phase: NEW
Lot: 46
Road #: 165 IRONWOOD BLVD
Structure: SINGLE FAMILY
of Bedrooms: 4
of People: 8
*Water Supply: N/A

System Specifications

Initial System

*Site Classification: Provisionally Suitable

Design Flow: 480

Soil Application Rate: 0.3000

*System Classification/Description:

TYPE II A. CONV SYSTEM (SINGLE-FAMILY OR 480 GPD OR LESS)

*Proposed System:
25% REDUCTION

Minimum Trench Depth: Inches

Maximum Trench Depth: 26 Inches

Septic Tank: 1000 Gallons

Pump Required ☐ Yes ☒ No ☐ May Be Required

Pump Tank: Gallons

Repair System Required: ☒ Yes ☐ No ☐ No, but has Available Space

Repair System

*Site Classification: Provisionally Suitable

Soil Application Rate: 0.300

*System Classification/Description:

TYPE II A. CONV SYSTEM (SINGLE-FAMILY OR 480 GPD OR LESS)

*Proposed System: 25% REDUCTION

Minimum Trench Depth: Inches

Maximum Trench: Depth: 26 Inches

Pump Required: ☐ Yes ☒ No ☐ May Be Required

Pump Tank: Gallons

No grading or construction activity is allowed in areas designated for system and repair without approval of Health Department.

*Site Modifications

The issuance of this permit by the Health Department in no way guarantees the issuance of other permits. The permit holder is responsible for checking with appropriate governing bodies in meeting their requirements.

*Permit Conditions

Please install septic system in accordance with attached design sheet(s) submitted by CCSC. Respect all setbacks.

CDP File Number: 399299

County ID Number:

The Department and Local Health Department may impose conditions on the issuance and may revoke the permits for failure of the system to satisfy the conditions, the rules, or this article. This permit is subject to revocation if the site plan, plat, or intended use changes (NCGS 130A-335(f)). The person owning or controlling the system location, installing, operation, maintenance, monitoring, reporting, and repair (.1938(b)).

Authorized State Agent: Jones, Lori Date of Issue: 09/11/2023

☐ Hand Drawing

☒ Import Drawing

****Site Plan/Drawing attached.****

Total Time: (HH:MM)

 :



File # 399299 Parcel ID: 047512
PIN# _____

Property Address: 165 Ironwood Blvd.

Applicant or Owner Name: Eastwood Yngs.
Honos Ral.

Environmental Health Septic/Well Permit Diagram

Building permits cannot be issued nor should construction begin without Construction Authorization issuance.

☒ Septic Improvement Permit ☒ Septic Construction Authorization (CA) ☐ CA Reissue** ☐ As Built
☐ Well Construction Authorization ☐ Additional Diagram/Specifications Attached

Diagram Date**: 9-11-2023 EHS: P. Jones

**Any previously dated CA diagram is revoked and/or invalid. Confirm this is the valid diagram for the site before beginning any construction.

Installation/grouting inspections may be scheduled the day before, or, the day of installation until 9am by contacting the Environmental Health office at 919 496 8100. A revisit fee may apply if installation is not ready for inspection at the time requested. Septic Operations Permits will be issued after installation is approved, all permits conditions are met, and any outstanding fees are paid. Well Certificate of Completion will be issued after well head approval, all permit conditions are met, and any outstanding fees are paid.

Septic Tank 1000 Pump Tank na Drainfield 3'x400' Type System Gravity/Serial Max Trench Depth 26"

Septic Contractor _____ Septic/Pump tank dates _____ Pump fee? NO YES pd _____

Well Contractor _____ Well GROUT date: _____

Bedrooms: 4


*Drawing submitted by Soil Scientist

Please install septic system in accordance with attached design sheet(s) submitted by CCSC. Respect all setbacks.

> Enclosures / Attachments

- *Keep tanks and drain lines 10' from property lines.
- *Not a survey.
- *Not a guarantee of a septic permit.
- *Keep supply lines >5' from property lines.
- *Some lines are flagged longer in the field than lengths indicate.
- *No grading septic area.

System:
Repair: _____



System: Gravity to Serial Dist.
Lines: 1-4, (400')
Accepted Status System
0.3 Soil LTAR
26" Trench Bottom

Repair: Gravity to Serial Dist.
Lines: 5-8, (400')
Accepted Status System
0.3 Soil LTAR
22" Trench Bottom

GRAPHIC SCALE
1" = 50'



Central Carolina Soil Consulting, PLLC
1900 South Main Street, Suite 110
Wake Forest, North Carolina 27587
Phone (919)569-6704 Fax (919)569-6703

4-Bedroom Septic Layout
Lot 46, Green Haven Subdivision
Franklin County, North Carolina

Job# : 2585
Drawn By : AH
Date : 08/9/2023
Revision: