

FRANKLIN COUNTY HEALTH DEPARTMENT

PERMIT NUMBER: 12181C CONST IMPROVE PERMIT	DATE: 01.22.99	0-1024	SIZE: 100X60
APPLICANT: WILLIAMS DONALD & TERI 320 SALT MARKET ST DUNN NC 28334 TELEPHONE: COMMENT:		OWNER: WILLIAMS DONALD & TERI 320 SALT MARKET ST DUNN NC 28334 DESCRIPTION: 5 YEAR ☐ LIFETIME: ☐	
LOCATION / DIRECTIONS:			
FEE: RE ROYALE #1024 125.00 10685		SIGNATURE OR OWNER OR AUTHORIZED AGENT:	


THE ABOVE SIGNATURE INDICATES THAT I HAVE READ, UNDERSTAND, AND AGREE WITH ALL PROVISIONS AND INFORMATION AS OUTLINED ON THE BACK SIDE OF THIS FORM

TOPO <u>PS</u>	TEXTURE <u>PS</u>	STRUCTURE <u>PS</u>	DEPTH <u>-</u>
R. HOR <u>PS</u>	SOIL. WET <u>S</u>	AVAIL. SP <u>PS</u>	OTHER <u>-</u>
MINRL <u>SE</u>	OVERALL <u>PS</u>	LTAR <u>.4</u>	
#BEDRMS <u>campus</u>	GPD <u>240</u>	DISPOSAL <u>-</u>	TYPE. SYS <u>Con/</u>
SZ. TANK <u>900 gal</u>	SZ. CHAMB <u>-</u>	NITRIFI <u>6'x70"</u>	TYPE. WAT <u>C</u>
SITE. LOC <u>-</u>	MAX TRENCH DEP <u>30"</u>	TYP. FAC <u>-</u>	

REMARKS: Setbacks: 5' prop-lines / foundation. Install 18" stone.

Mills-1000
STB-858

Bobby Marshall



IMPROVEMENT PERMIT DATE: <u>1-28-99</u>	ENV HEALTH SPEC: <u>[Signature]</u>
CONSTRUCTION AUTHORIZATION DATE: <u>1-28-99</u>	ENV HEALTH SPEC: <u>[Signature]</u>
OPERATION PERMIT DATE: <u>2-13-99</u>	ENV HEALTH SPEC: <u>[Signature]</u>

FRANKLIN COUNTY HEALTH DEPARTMENT

PERMIT NUMBER: 12181C CONST IMPROVE PERMIT	DATE: 01.22.99	# 0-1024	SIZE: 100X60
APPLICANT: WILLIAMS DONALD & TERI 320 SALT MARKET ST DUNN NC 28334 TELEPHONE: 897-5452		OWNER: WILLIAMS DONALD & TERI 320 SALT MARKET ST DUNN NC 28334	
COMMENT:		DESCRIPTION: 5 YEAR ☐	LIFETIME: ☐
LOCATION / DIRECTIONS:			
FEE: KE ROYALE #1024 125.00 10685		SIGNATURE OR OWNER OR AUTHORIZED AGENT:	


THE ABOVE SIGNATURE INDICATES THAT I HAVE READ, UNDERSTAND, AND AGREE WITH ALL PROVISIONS AND INFORMATION AS OUTLINED ON THE BACK SIDE OF THIS FORM

TOPO <u>PS</u>	TEXTURE <u>PS</u>	STRUCTURE <u>PS</u>	DEPTH <u>-</u>
R. HOR <u>PS</u>	SOIL. WET <u>3</u>	AVAIL. SP <u>PS</u>	OTHER <u>-</u>
MINRL <u>YE</u>	OVERALL <u>PS</u>	LTAR <u>.4</u>	
#BEDRMS <u>campfire</u>	GPD <u>240</u>	DISPOSAL <u>—</u>	TYPE. SYS <u>Con1</u>
SZ. TANK <u>900 gal</u>	SZ. CHAMB <u>—</u>	NITRIFI <u>6'x70"</u>	TYPE. WAT <u>C</u>
SITE. LOC <u>—</u>	MAX TRENCH DEP <u>30"</u>	TYP. FAC <u>—</u>	

REMARKS: Setbacks: 5' prop-lines / foundation. Install 18" stone.

Mills - 1000
STB - 858

Bobby Marshall



IMPROVEMENT PERMIT DATE: <u>1-28-99</u>	ENV HEALTH SPEC: <u>[Signature]</u>
CONSTRUCTION AUTHORIZATION DATE: <u>1-28-99</u>	ENV HEALTH SPEC: <u>[Signature]</u>
OPERATION PERMIT DATE: <u>2-13-99</u>	ENV HEALTH SPEC: <u>[Signature]</u>

SEPTIC PERMIT APPLICATION
Franklin County Health Department
Phone 496-8100

TxREC#: 0
PIN#:

12181C
SPermit#: 0
BPermit#: 12482
TMAP:

Township: Lake Royale
Subdivision: Lake Royale
Prop.Address:

Zone:
Lot: 1024 Lot Size: 100x60
St.Road:

Applicant: Williams, Donald & Teri
Address: 320 Salt Market Street
C/S/Z: Dunn, NC 28334
Phone: (910) 897-5452
SF/Building Permit:
Bedroom#: 0
Commercial:
Public Sewer:
Public Water:
Type Facility:
SPermit \$:125.00
Notes:

Owner: Williams, Donald & Teri
Address:
C/S/Z:

Mobile Home Permit:
Bath#: 0.0
Industrial:
Town:

Est.Daily Waste Flow:
Date: 01/22/99 Rec#: 10685

ZONING PERMIT

Department of Planning & Development

Use of Property: Camper light

Zoning District:

Setback Required: Front:

Rear:

Side:

Kathy Tharrington

Zoning Administrator

I certify that all the statements made in this application and any attached documents are true, complete and correct to the best of my knowledge and belief and are made in good faith. I understand that false information may be grounds for rejection of this application. Authorized County representatives are granted right of entry to make evaluations or inspections and to release information upon public request.

Teri Williams

1/22/99

Signature of Owner/Authorized Agent

Date

Call the Health Department (496-8100) between 8:00 AM and 9:00 AM on Monday-Friday to schedule an appointment with an environmental health specialist to evaluate your lot. He/she will show you where to locate the well and septic system, in relation to the desired dwelling location and any property lines. If approved, an improvements permit will be issued. After the septic tank has been installed and approved, the Sanitarian will issue a certification of completion.