

Stallings 1-80

Application Date: 09/13/2004

APPLICATION

Application #: WLS2004-01187
Project #: PRJ2004-02169



PITT COUNTY DEVELOPMENT SERVICES
ENVIRONMENTAL HEALTH
1717 W 5th Street
Greenville, NC 27834-1696
Office (252) 902-3200

Type Of Inspection: Evaluation for a New Septic System
Appointment Req'D: No Fees Paid ☒ yes ☐ no
Additional Fee For Sys Design: Fees Paid ☐ yes ☒ No
Site Ready For Eval/Inspection: 09/11/2004

Applicant: STEVEN KRPATA
Address: 1968-B QUAIL RIDGE RD
GREENVILLE, NC 27858
Pri Phone: 252-341-8626

Land Owner: ROBERT W MCCONNELL
Address: 3022 DARMOUTH DRIVE
GREENVILLE, NC 27858
Pri Phone:

Other Number: _____ Other Number: _____

Subdivision Name: ~~Steven Krpata~~ Ashley Place Lot #: 2 Block: _____ Parcel #: 22785
Lot Size: _____ 71919

Directions: FIRETOWER RD TO PORTERTOWN RD & TURN RIGHT. PROPERTY ON LEFT ACROSS FROM RAYNEZ POOL. PROPERTY IS ADJACENT TO WALDEN S/D. 3305 Ashley Pl

Type of Use: House Water Supply: Eastern Pines Water Corporation
of Children: _____ # of Bedrooms: 4 # of Employees: _____ # of Seats: _____

Greenville ETS
9/14/04

Applicant's Signature _____ Owner (or) _____ Owner's Representative

IMPROVEMENT PERMIT

Tank Size 1000 Pump Tank _____ Nitrification Field Eg 900ft² Trench Bottom Depth 30.18"
System Type ITL6 Estimated Flow 480 GPD Date of Eval(s) 10-4-04 Plot Plan Required YES

Remarks: Do not drive/build over system/repair area

Permit Reference #'s _____

An authorization to construct a wastewater system must be obtained from environmental health before construction of the wastewater system begins. Depending on the system design, an additional fee may be charged before the authorization to construct can be issued.

Date Issued: 4.15.05 Environmental Health Specialist [Signature]
Date Approved: 2.21.06 Environmental Health Specialist [Signature]


(GS130A-335) This improvement permit is subject to revocation if the site is altered or if the site plan or intended use change.

Improvement Permit Valid ☒ No Expiration ☐ 5 (five) Years

PETER B. WAGNER
D.B. 587, PG. 243

AUTHORIZATION TO CONSTRUCT
BY [Signature]
DATE 4-15-05
PERMIT # WCS 2004-01187
Valid for Five (5) Years
OR Expiration Date of Permit

MICHAEL BIGGER
D.B. 332, PG.



PITT COUNTY SOIL SITE EVALUATION FOR ON-SITE WASTEWATER SYSTEM

DATE: 10.4.04

PARCEL # 22745

APPLICATION # WLS2004-01187

APPLICANT: Steven Krpata

DATE EVALUATED: 10.4.04

PROPOSED FACILITY: 4 BR Home

PROPERTY SIZE: See Map

LOCATION OF SITE: Per textown Rd Ashley ~~way~~ Place Steven Krpata Lot 2

DESIGN FLOW: 480 GPD

WATER SUPPLY: ON-SITE WELL COMM. WELL PUBLIC OTHER

EVAL METHOD: AUGER BORING PIT

PRO-FILE	.1940 LANDSCP POS./SLOPE	HORI. DEPTH (IN.)	(a) (1) TEXTURE	(a) (2) STRUCTURE	(a) (3) MINERA./CONSIS.	MATRIX COLOR	MOTTLE COLOR	OTHER PROFILE FACTORS
9		0-6	SL	SBK	VFR	2.5Y6/4		.1942 WETNESS COND. - 248"
		6-26	SL	SBK	VFR	10YR5/6	TOR 06"	.1943 DEPTH/.1956 SAPR. - NA
		26-42	SCL	SBK	FR	2.5Y5/6	due to slope	.1944 RESTRICTIVE HORI. - NA
		42-48	SL	SBK	VFR			.1948 PROFILE CLASS. - PS
								PROFILE LTAR - .4
10		0-6	SL	SBK	VFR			.1942 WETNESS COND. - 242"
		6-30	SL	SBK	VFR	2.5Y6/4	TOR 06"	.1943 DEPTH/.1956 SAPR. - NA
		30-42	SCL	SBK	FR	10YR5/6		.1944 RESTRICTIVE HORI. - NA
								.1948 PROFILE CLASS. - PS
								PROFILE LTAR - .4
11		0-12	SL	SBK	VFR			.1942 WETNESS COND. - 42"
		12-24	SL	SBK	VFR	2.5Y6/4	TOR 06"	.1943 DEPTH/.1956 SAPR. - NA
		24-42	SCL	SBK	FR	10YR5/6		.1944 RESTRICTIVE HORI. - NA
								.1948 PROFILE CLASS. - PS
								PROFILE LTAR - .4
12		0-3	SL	SBK	VFR			.1942 WETNESS COND. - 30"
		3-12	SL	SBK	VFR	2.5Y6/4	TOR 06"	.1943 DEPTH/.1956 SAPR. - NA
		12-30	SCL	W SBK	FR	10YR5/6		.1944 RESTRICTIVE HORI. - NA
		30-48	SCL/SCL	SBK	FR	10YR5/6	2.5Y6/2 streaks	.1948 PROFILE CLASS. - PS
								PROFILE LTAR - .3

AVAILABLE SPACE (.1945) OTHER FACTORS (.1946) SITE CLASSIFICATION (.1948) PS

SYSTEM TYPE HPC LONG-TERM ACCEPTANCE RATE (S) .4 S/S / .3 RA

VALUATED BY: [Signature] OTHER (S) PRESENT:

COMMENTS:

See Map for boring locations

PITT COUNTY PUBLIC HEALTH CENTER

Environmental Health Division

1717 W. 5th Street • Greenville, NC 27834

OPERATION PERMIT

Ground Absorption Sewage Disposal System
NC General Statutes Chapter 130A-Article 11

Owner Kraba Steven
Last First Middle

Location Ashley Place lot 2 3305 Ashley PI

Type Use: Residence Home # Bedrooms 4

Other _____ H₂O Supply TEP

System Type: JUL6 Review Freq. _____

Tank Cap. 1000 Mfgt. San Serial # STB-787

Sq. Ft. 1700 # Lines 4 Width 3' Cover KG-10"

Pump Tank Cap. _____ Mfgt. _____ Serial # _____

Grease Trap Cap. _____ Mfgt. _____ Serial # _____

Filter Kalylak Pump _____

Comments 19 barrels / line of Quick 4-W

Installed by Stallings

Inspected by [Signature]

PERMIT # WLS2004-01187-B

Date Approved 2-21-06

Tax Parcel # 22-185 71919

New _____ Existing _____ Repair _____

