


11.1542/87



Wayne County (Environmental) – Improvements Permit

301 N. Herman Street, Box CC, Goldsboro, NC 27530
 Phone:(919) 731-1174
 Fax:

Final

Permit No: 21070106957
Status: ISSUED

Appl. Dt.: 10/14/2021 **Exp. Dt.:** 10/14/2026
Status Dt.: 8/29/2023

Owner Information

Name : J & N Developers Llc
Address : PO Box 658
 Princeton NC 27569
Phone(W) :
Phone(H) :
Phone(M) :

Property Information

PIN # : 113604552879
Address : 103 Fynloch Chase Dr
 Fremont NC 27830
Acreage : 0.50
Subdivision : Fynloch Chase
Lot # : 87
Directions :
Watershed district :

Site Details

System Classification : Type III
System Description : Other non-conventional trench sys
Line Length : 4(60x3)
Line Depth : 24.00
Nitrification Sq. Ft. : 720.00
Tank #1 : Septic Tank - 900.00
Tank #2 :
Tank #3 :

Applicant Information

Name : J & N Developers Llc
Address : PO Box 658
 Princeton NC 27569
Phone(W) :
Phone(H) :
Phone(M) :

Occupant Information

Name : J & N Developers Llc

Water Details

System : New
Source : Public

Property Characteristics


Type of establishment : Residential dwelling units
Number of establishment : 3 Bedrooms
Septic GPD : 360
Basement : No
Basement Bath : No
Garbage Disposal : No
Multiple Dwelling Units : No
Property Notes : 6 occupants max.

Permit Information

Septic System Requested :
System Description Requested :

Notes : Install 25% reduction system. Trenches will start at 24" deep and end at 12" deep. Some soil cover may be needed.

Inspections Conducted

Inspections	Signed Off/User ID	Date	Status	Reason
IP	EHKWHITLEY	2/28/2023	OK/S	
ATC	EHKWHITLEY	2/28/2023	OK/S	
OP	EHKWHITLEY 	8/29/2023	OK/S	

Payment Information

--	--	--	--	--	--	--	--	--	--

WAYNE COUNTY DEPARTMENT OF PUBLIC HEALTH



WAYNE COUNTY
NORTH CAROLINA


Operation Permit

PIN: 113604552879 Permit Number: 21070106957
 Subdivision or Road: Fynloch Chase Lot#: 87 Section: _____
 Specific System Installed: Infiltrator
 Septic Tank: 1000 gallons Pump Tank: N/A gallons Trench Length: 4(60x3) feet
 System Type: III GPD: 360 Number of Bedrooms: 3 Maximum number of occupants: 6

Types V and VI systems expire in 5 years in Accordance With Table Va. Owner must contact health department 6 months prior to expiration for permit renewal.

J&N Developers
 Owner's Name
Kevin Whitley
 Authorized State Agent

Randy Batten
 System Installer
8-29-23
 Date of Operation Permit Issuance



This system has been installed in compliance with applicable NC General Statutes, Rules for Sewage Treatment and Disposal, and all conditions of the Improvement Permit and Construction Authorization.

PERMIT CONDITIONS:

- I. Performance: System shall perform in accordance with Rule .1961.
- II. Monitoring: As required by Rule .1961.
- III. Maintenance: Ground absorption sewage treatment and disposal systems shall be checked, and the contents of the septic tank removed, periodically from all compartments, to ensure proper operation of the system. The contents shall be pumped whenever the solids level is found to be more than 1/3 of the liquid depth in any compartment.

Other: _____
 Subsurface system operator required? Yes ___ No ___ (If yes, see attached sheet for additional operation conditions, maintenance and reporting.)

IV. Operation: _____
 V. Other: _____

THE GOOD LIFE. GROWN HERE.

301 NORTH HERMAN STREET
 BOX CC
 GOLDSBORO, NC 27530