

COUNTY ENVIRONMENTAL HEALTH DEPARTMENT

309 E. Market Street
Smithfield, North Carolina 27577
Telephone: 919-989-5180 • Fax: 919-989-5190

Application # 70599 Parcel # 15HD9010
 Name: Carl Langdon Address: 311 Lassiter Rd. F. OAKS
 Location: 210 1/2 Black Creek Tr Lassiter on left 300'
 Facility - Type: SFD 90x116 S/D & Lot # Carl Langdon
 Soil Site Classification: PS LTAR: .36
 Bedrooms: 4 Design Daily Sewage Flow: 480 gpd Lot Area: ±93A-
 New Construction: Yes Repair: No Upgrade: No Water Supply: Public
 Septic Tank Size: 1000+ Grease Trap Size: 1
 Pump Tank Size: 1 Pump(s) Size: 1
 Drainfield Type: Com - Accepted Square Feet: 1320
 # of Lines: 4 Width: 3 Length: 4-110 Depth: 18-22"
 Design/Layout by: MJS Improvement Permit Issued by: MJS Date: 6/27/05 Exp. Date 6/27/10
 Inspection: Lines: MS 3-150-GTR Septic Tank: MCP1000 D-Box: MS
 Pump Tank: 1 Pump(s)/Pressure: 1
 Drainage: 1 Contractor: Ivey

AUTHORIZATION FOR WASTEWATER SYSTEM CONSTRUCTION

ISSUED BY: [Signature] DATE ISSUED: 6/27/05

By rule, this septic system requires the use of an effluent filter and a waterproof seal. A riser and septic marker may also be required. Systems shall be installed as shown in sketch or according to attached plans and specifications. Any unauthorized site disturbance, filling, soil removal, or layout changes may result in the permit being revoked. Improvement permit is valid for 5 years from date of issuance unless otherwise indicated. The owner/agent accepts & verifies the conditions of the permit as indicated below.

OWNER/AGENT: [Signature] DATE: 6/27/05

