



Construction Authorization

P.O. BOX 948
KENANSVILLE, NC 28349
Phone: 910-296-2126 Fax: 910-296-0250

For Office Use Only

*CDP File Number: 430416 - 2
 County ID Number: 06-1175- - 33321
 Evaluated For: NEW

PERMIT VALID UNTIL: 11/22/2029
 Open Pump System Sheet

Applicant: GINA SANDERSON
 Address: 2485 N NC HWY 111
 City: PINK HILL
 State/Zip: NC 28572
 Phone #: home: (910) 358-5489

Property Owner: GINA SANDERSON
 Address: 2485 N NC HWY 111
 City: PINK HILL
 State/Zip: 28572
 Phone #: home: (910) 358-5489

Property Location & Site Information

Address/Road #: N NC 111 HWY PINK HILL, NC 28572 Subdivision: _____ Phase: NEW Lot: 8
 Structure: MOBILE HOME **Directions:** N NC 111 HWY
 # of Bedrooms: 3
 # of People: _____
 *Water Supply: _____

System Specifications

Usuable Soil Depth: _____ Minimum Trench Depth: _____ Inches
 Design Flow: 360 Maximum Trench Depth: 30 Inches
 Soil Application Rate: 0.6000 Minimum Soil Cover: _____ Inches
 *System Classification/Description: TYPE II A. CONV SYSTEM (SINGLE-FAMILY OR 480 GPD OR LESS) Maximum Soil Cover: _____ Inches
 *Proposed System: _____ *Distribution Type: GRAVITY - PARALLEL (eq. d-box)

Nitrification Field: 600 Sq. ft. Septic Tank: 1,000 Gallons
 No. Drain Lines: 4 Pump Required: Yes No May Be Required
 Total Trench Length: 50 ft. Inches O.C. Pump Tank: _____ Gallons
 Trench Spacing: 9 - _____ Feet O.C. Grease Trap: _____ Gallons
 Trench Width: 36 - _____ Inches Septic Tank Installer
 Aggregate Depth: _____ inches Feet Grade Level Required: I II III IV

The issuance of this permit by the Health Department in no way guarantees the issuance of other permits. The permit holder is responsible for checking with appropriate governing bodies in meeting their requirements.

*Permit Conditions:

TRENCH BOTTOM DEPTH NO DEEPER THAN 30 INCHES.

The Authorization for Wastewater System Construction shall be valid for a period equal to the period of validity of the Improvement Permit and may be issued at the same time the Improvement Permit issued (NCGS 130A-336(b)). If the installation has not been completed during the period of validity of the Construction Permit, the information submitted in the application for a permit or Construction Authorization shall become invalid, and may be suspended or revoked (.0204(k)(1)). The person owning or controlling the system shall be responsible for assuring compliance with the laws, rules, and permit conditions regarding system location, installation, operation, maintenance, monitoring, reporting and repair (per rule .0301((a)).

Authorized State Agent: Kennedy, Adam Date of Issue: 11/22/2024

****Site Plan/Drawing attached.****

Total Time : (HH:MM) _____

Hand Drawing Import Drawing