

Michelle R. Meads

From: kris vick
<k.vick1208@gmail.com>
Sent: Tuesday, May 11, 2021 12:05 PM
To: Michelle R. Meads
Subject: Septic Report - 585 Old Swamp Rd

CAUTION: This message originated from an email address outside the agency. Please do not click any links or open any attachments unless verified. Send all suspicious email as an attachment to Report.Spam

Good afternoon,

1

Do you have a septic report available for 585 Old Swamp road, owners Epperly?
Thank you,

*Best Regards,
Kris Vick*



Royal Realty Group, LLC
2878 Caratoke Hwy,
Currituck NC, 27929
Office (252) 232-2777

2

K.VICK1208@gmail.com



ALLEGHENY REGIONAL HEALTH SERVICES
Partners in Public Health

Camden

Permit: 234002

PIN:

Owner:
EPPERLY, BENJAMIN
118 KEETER BARN ROAD
SOUTH MILLS, NC 27976

Applicant:
EPPERLY, BENJAMIN
118 KEETER BARN ROAD
SOUTH MILLS, NC 27976

LTAR: 0.200
Water: ~~POUND~~ WELL
TYPE III G.
SINGLE FAMILY
GPD: 360


Location:
OLD SWAMP ROAD

SEPTIC TANK MUST BE HIGH ENOUGH
SO THAT TRENCH BOTTOM IS NO
DEEPER THAN 12 INCHES BELOW TOP
OF FILL. 2 FT OF FILL IS REQUIRED.
TOP OF TANK SHOULD BE ABOUT 30"
ABOVE EXISTING GRADE!


*FILL MOUND MUST BE
60 FT BY 120 FT BY 24"*

EXCAVATE 6 LINES 100 FT
LONG, 9 FT ON CENTER TO A
DEPTH OF 5 FT BELOW ORIGINAL
GRADE, BACKFILL WITH 6 FT OF
COARSE SAND AND INSTALL 12"
OF TRENCH MATERIAL.

KEEP ALL PARTS OF SEPTIC
SYSTEM AT LEAST 50 FT
FROM POND AT 589 OLD SWAMP ROAD




*HOUSE
589*



DRIVEWAY
PATH TO OLD SWAMP ROAD

*HOUSE
583*

Authorized Agent:  REVIS 1911
Swinney, David

Date: 02/22/2017

Approved:  REVIS 1911

Date: 9/13/17

