RESIDENTIAL WELL CONSTRUCTION RECORD

339836

North Carolina Department of Environment and Natural Resources- Division of Water Quality

WELL CONTRACTOR CERTIFICATION # 2460

1. WELL CONTRACTOR:

RAY MANESS
Well Contractor (Individual) Name

TW TW MANESS & SON'S
Well Contractor Company Name

STREET ADDRESS 196 Woodrow rd
Robbins NC 27325
City or Town State Zip Code

(919) 663-3891
Area code- Phone number

2. WELL INFORMATION:

SITE WELL ID #(if applicable)

STATE WELL PERMIT#(if applicable)

DWQ or OTHER PERMIT #(if applicable) Moore Co Perm.

WELL USE (Check Applicable Box): Residential Water Supply ☒

DATE DRILLED 3-21-07

TIME COMPLETED 2:30 AM ☐ PM ☒

3. WELL LOCATION:

CITY: Carthage COUNTY Moore

The Fields Lot-10-28327
(Street Name, Numbers, Community, Subdivision, Lot No., Parcel, Zip Code)

TOPOGRAPHIC / LAND SETTING:

☒ Slope ☐ Valley ☐ Flat ☐ Ridge ☐ Other
(check appropriate box)

LATITUDE 35° 20.796'
LONGITUDE 079° 20.115'

May be in degrees, minutes, seconds or in a decimal format

Latitude/longitude source: ☒ GPS ☐ Topographic map
(location of well must be shown on a USGS topo map and attached to this form if not using GPS)

4. WELL OWNER

OWNER'S NAME Anthony & Carol Pressicci

STREET ADDRESS 230 Red Fox ridge
Carthage NC 27327
City or Town State Zip Code

631) 219-1074
Area code - Phone number

5. WELL DETAILS:

a. TOTAL DEPTH: 600

b. DOES WELL REPLACE EXISTING WELL? YES ☐ NO ☒

c. WATER LEVEL Below Top of Casing: 25 FT.
(Use "+" If Above Top of Casing)

d. TOP OF CASING IS 12 FT. Above Land Surface*
*Top of casing terminated at/or below land surface may require a variance in accordance with 15A NCAC 2C .0118.

e. YIELD (gpm): 1 METHOD OF TEST A/R

f. DISINFECTION: Type HTH Amount 3 CUPS

g. WATER ZONES (depth): FT

From	To	From	To
19 pm	58		

6. CASING:

From	To	Diameter	Thickness/ Weight	Material
0	56	4	SDR21	PVC

7. GROUT:

From	To	Material	Method
0	20	Sand/cement	Poured

8. SCREEN:

From	To	Diameter	Slot Size	Material

9. SAND/GRAVEL PACK:

From	To	Size	Material

10. DRILLING LOG

From	To	Formation Description
0	10	Sand
10	50	Brown Slate
50	600	Triasic rd

RECEIVED
DIV. OF WATER QUALITY
APR 02 2007

11. REMARKS:

I DO HEREBY CERTIFY THAT THIS WELL WAS CONSTRUCTED IN ACCORDANCE WITH 15A NCAC 2C, WELL CONSTRUCTION STANDARDS, AND THAT A COPY OF THIS RECORD HAS BEEN PROVIDED TO THE WELL OWNER.

Ray Maness 3-23-07
SIGNATURE OF CERTIFIED WELL CONTRACTOR DATE

RAY MANESS
PRINTED NAME OF PERSON CONSTRUCTING THE WELL

Submit the original to the Division of Water Quality within 30 days. Attn: Information Mgt., 1617 Mail Service Center – Raleigh, NC 27699-1617 Phone No. (919) 733-7015 ext 568.

Form GW-1a
Rev. 7/05