

EHDP 2012 - 01334

ONSWLOW COUNTY HEALTH DEPT.

OPERATIONS PERMIT
(GS 130A-337)

Permit No.: 16777

Systems Type: ITC 1130

Owner: Queens Village
Address: Lot 11A Section 1
Location: Next to 204 Kings Parkway
Sr#: NCSR 1602

THIS DOES NOT CONSTITUTE A WARRANTY OR GUARANTEE.

Installed By: Randy Arnold
Signed By: Sam Fzelle
Date: 9-13-06

FINAL PLOT / REMARKS
6-18-06
System type page 1000
STB 134
Manufacturer _____
Model# _____
3 Bedroom Residence / \approx 360 gpd

ONSWLOW COUNTY HEALTH DEPT.

CONSTRUCTION AUTHORIZATION
(GS 130A-336)

THIS AUTHORIZATION FOR WASTEWATER SYSTEM CONSTRUCTION SHALL BE VALID FOR A PERIOD EQUAL TO THE PERIOD OF VALIDITY OF THE IMPROVEMENT PERMIT, NOT TO EXCEED 5 YEARS.

Permit No.: 16777

Fee: System Type ITC

Owner: Queens Village
Address: Lot 11A Section 1 Parcel # 1313B 29, 1
Location: Next to 204 Kings Parkway
Sr#: NCSR 1602

System Type/Description: Shallow Conventional LTAR: 0.4 gpd/sq. ft.
Septic Tank Size: 2,900 gallons
Nitrification Area: 900 sq. ft. 300 lin. ft.
No. of lines: 4 Line length 75ft x 3ft
Trench bottom depth: 18 inches

(SEE ATTACHED PAGES 1 of 1 FOR ADDITIONAL PERMIT CONDITIONS)

Signed: Sam Fzelle Date: 3-15-06

ONSWLOW COUNTY HEALTH DEPT.

IMPROVEMENT PERMIT
(GS 130A-336)

- Valid for 5 years from date of issuance.
- Valid without expiration.

Permit No.: 16777

Fee: System Type ITC

Owner: Queens Village
Address: Lot 11A Section 1
Location: Next to 204 Kings Parkway
Sr#: NCSR 1602

System Type/Description: Shallow Conventional LTAR: 0.4 gpd/sq. ft.
Facility/Daily design flow: 3 Bedroom Residence / \approx 360 gpd
Water supply: On-site well Comm. well _____ Public _____ Other _____

(SEE ATTACHED PAGES 1 of 1 FOR ADDITIONAL PERMIT CONDITIONS)

Signed: [Signature] R.S. Date: 16 Aug 05

NOTE: Permit is subject to revocation if site plans or intended use change.

Buff Ledger: **ORIGINAL** Blue: **BUILDING INSPECTION** Pink: **CLIENT**

Owner: Queens Village
 Address: Lot 11A Section 1
 Location: Next to 204 Kings Parkway

