

NEW

REPAIR

EXPANSION

PANICO COUNTY HEALTH DEPARTMENT

P.O. BOX 306

BAYBORO, N.C. 28515

IMPROVEMENT PERMIT

C176

Permit valid for:

Five (5) years

No expiration

Maximum allowed:

# Bedrooms

# Occupants

# Seats

43.6

6

6

Owner: James Elam

Owner Address: 1905 Sea Oats Avenue, FL 32034

Owner Phone #: (305) 215-0535

Property Address: 213 Cassie May Blvd

Property Address(2): Oriental, NC 28571

Record #80898

Establishment Type: Home

Type of Well: Public Well (county)

Design Flow (GPD): 360

Initial Site

Wastewater System: Accepted System

Long Term Acceptance Rate (GPD/SQFT): 0.4

Trench Width: 3 FT

Trench Spacing (OC): 9 FT

Trench Bottom From NGL: 20 IN

Septic Tank Volume: 1000 GAL

Install 3 lines (75') 20" deep maximum

Repair Site

Wastewater System: Accepted System

Long Term Acceptance Rate (GPD/SQFT): 0.4

Trench Width: 3 FT

Trench Spacing (OC): 9 FT

Trench Bottom From NGL: 20 IN

Septic Tank Volume: 1000 GAL

Repair Site

Wastewater System: Accepted System

Long Term Acceptance Rate (GPD/SQFT): 0.4

Trench Width: 3 FT

Trench Spacing (OC): 9 FT

Trench Bottom From NGL: 20 IN

Septic Tank Volume: 1000 GAL

SYSTEM TYPE:

Accepted

Alternative

Conventional

Innovative

The Pamlico County Health Department reserves the right to revoke this permit if the site is altered, intended use changes, or there is a change in the site plan or plat. Improvement Permit shall not be affected by change in ownership of the site.

An Authorization to Construct must be obtained prior to wastewater system construction

Authorized Agent: *Tracy C. Harris* #1524 Date 7/22/2015

