



Martin-Tyrrell-Washington

DISTRICT HEALTH



Public Health
Prevent Promote Protect

252.793.3023 (p) • 252.791.3108 (f) • mtwdistricthealth.org

PIN _____

MARTIN COUNTY HEALTH DEPARTMENT

Permit Number

IMPROVEMENT PERMIT

A building permit cannot be issued with only an Improvement Permit

ISSUED TO: Joshua Stalls

PROPERTY LOCATION: Parcel 0600646

Prison Camp Road

Williamston, NC 27892

ADDRESS: 1150 Guss Lane
Williamston, NC 27892

New Repair _____ Expansion _____

Site Improvements required prior to Construction Authorization Issuance:

Type of Structure: 4 Bedroom Residence

Proposed Wastewater System Type: Conventional

Projected Daily Flow: 480 GPD

Number of bedrooms: 4 Maximum Number of Occupants: 8

Basement: _____ Yes No

Pump Required: _____ Yes _____ No May be required based upon final location and elevations of facilities.

Type of Water Supply: Public Water

Permit valid for: Five years
_____ No expiration

Permit conditions: _____

Authorized State Agent: Andrew Parker RBHS Date: 8/2/2024

See Attached Site Sketch

The issuance of this permit by the Health Department in no way guarantees the issuance of other permits. The permit holder is responsible for checking with appropriate governing bodies in meeting their requirements. This site is subject to revocation if the site plan, plat, or the intended use changes. The Improvement Permit shall not be affected by a change in ownership of the site. This permit is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to conditions of this permit

Martin County
210 W. Liberty St.
Williamston, NC 27892
252.793.1619

Tyrrell County
408 Bridge St.
Columbia, NC 27925
252.793.1750

Washington County
198 Hwy. 45 North
Plymouth, NC 27962
252.793.3023



CONSTRUCTION AUTHORIZATION

(Required for Building Permit)

The construction and installation requirements of Rules .1950, .1952, .1954, .1955, .1956, .1957, .1958, and .1959 are incorporated by reference into this permit and shall be met. Systems shall be installed in accordance with the attached system layout.

ISSUED TO: Joshua Stalls

PROPERTY LOCATION: Parcel 0600646

Prison Camp Road
Williamston, NC 27892

ADDRESS: 1150 Guss Lane
Williamston, NC 27892

Facility Type: 4 Bedroom Residence New Expansion Repair
Basement? Yes No Basement Fixtures? Yes No
Type of Wastewater System** Conventional (Initial) Wastewater Flow: 480 GPD
(See note below, if applicable)
Conventional (Repair)

Installation Requirements/Conditions

Septic Tank Size: 1,000 gallons.

Pump Tank Size: N/A gallons. Pump requirements: _____ ft. TDH vs. _____ GPM.

Total Trench Length: 320 feet. Maximum Trench Depth of: 12 inches.

Trench Spacing: 9 feet on Center. Soil Cover: 6 inches cover minimum.

Aggregate Depth: 12 inches.

Trench bottoms shall be level to +/- 1/4" in all directions. Maximum soil cover shall not exceed 36" above trench bottom.

Conditions: see site sketch

****If applicable:**

I understand the system type specified is different from the type specified on the application. I accept the specifications of this permit.

Owner/Legal Representative Signature: _____ Date: _____

This Construction Authorization is subject to revocation if the site plan, plat, or the intended use changes. The Construction Authorization shall not be transferred when there is a change in ownership of the site. This Construction Authorization is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to the conditions of this permit.

Authorized State Agent: Andrew Porter RBHS Date of Issuance: 8/2/24

See Attached site sketch

Construction Authorization Expiration Date: August 2, 2029

PAGE 1 OF 2

Site Sketch

PIN: Permit Number: () Improvement Permit (✓) Construction Authorization

Joshua Stalls
Applicant's Name

Parcel 0600646 Prison Camp Road Williamston, NC 27892
Subdivision/Section/Lot Number

Andrew Ponton RBHS
Authorized State Agent

8/2/2024
Date

System components represent approximate contours only. The contractor must flag the system prior to beginning the installation to ensure that the proper grade is maintained.

Scale = Not to Scale

Conditions:

- 1,000 Gallon Septic Tank.
- Install 4 trenches at 80 feet in length as shown. Trenches sized for Conventional Gravel trench material.
- Maximum trench depth of 12 inches. With a minimum 6-inches of soil cover. Grade to divert surface water.
- If gravity fall to trenches cannot be achieved, then a pump tank may be required.
- Do not drive or build over septic system or repair area.

