

MOORE COUNTY HEALTH DEPARTMENT
ENVIRONMENTAL HEALTH SECTION
P.O. Box 279 Carthage, N.C. 28327
Phone: 947-2858

APPLICATION FOR AN IMPROVEMENT PERMIT
FOR A SUBSURFACE SEWAGE DISPOSAL SYSTEM

PROPERTY I.D. # LOT # 94B CARDINAL CIR.
WHISPERING PINES, NC

THE FOLLOWING MUST BE COMPLETED PRIOR TO SITE EVALUATION:

1. Applicant is responsible for obtaining zoning compliance, when required.
2. Clearly mark the location of all property boundaries and the corners of the proposed building(s).
3. Dig three(3) holes approximately 50' apart, forming a triangle in the desired system location. The holes should be a minimum of 6" in diameter 24" deep.
4. A site plan must be submitted showing any improvements, house location, driveways, existing water supplies, etc.

OWNER PAUL + ALICE PARDY PHONE 919-261-6826

ADDRESS 4 SOUNDVIEW TRAIL, SOUTHERN SHORES NC 27949

APPLICANT/REPRESENTATIVE R.F. BLAUW REALTOR PHONE OFFICE: 919-692-2635
HOME: 919-692-3150

EXACT DIRECTIONS TO PROPERTY (FROM CARTHAGE) 15/501 to 22 to LEFT AIRPORT

1st
ROAD to RIGHT ON CARDINAL CIR. LOT # 94B ON LEFT

TYPE OF FACILITY SINGLE FAMILY HOME

OF BEDROOMS 3 GARBAGE DISPOSAL (Yes/No) NO

OF BATHROOMS 2 DISHWASHER (Yes/No) YES

OF PEOPLE SERVED 2 WASHING MACHINE (Yes/No) YES

BASEMENT (Yes/No) NO GARAGE
BASEMENT PLUMBING (YES/NO) YES

ADDITIONAL FACTORS AFFECTING DAILY FLOW RATE (Water Saving Fixtures, Jacuzzi, etc.)

LIST: JACUZZI

WATER SUPPLY: PUBLIC: PRIVATE TYPE

ARE THERE ANY WATER SUPPLIES ON ADJOINING PROPERTY? YES NO

IS THIS PROPERTY IN A ZONED AREA? YES NO COMPLIANCE OBTAINED?

DATE PROPERTY WAS DEEDED AND RECORDED


TRI-PARTY AGREEMENT PROVIDED FOR MULTI-FAMILY UNITS OR CONDOS N/A

Paul J. Hardy, Alice M. Hardy June 15, 1992
Signature of Applicant Date
Original to - Health Department Copy to - Applicant

MCHD ENV - 1/92

SELLER: PHILIP WATSON
BUYERS: PAUL T. PAROY
ALICE M. PAROY

LOT 94B SEC. 9
CARDINAL CIR.
W/ HERRING PINES, N.C.



SITE / SOIL EVALUATION FOR SANITARY SEWAGE SYSTEM

OWNER: Jan' Rudy PHONE: _____ DATE REQUESTED: _____ DATE EVALUATED: 7-14-92
 ADDRESS: Wh. Pines PROPERTY IDENTIFICATION NO.: _____
 COUNTY: Moore PROPERTY SIZE: _____ PROPOSED FACILITY: House
 LOCATION OF SITE: Lot 94-B Whispering Pines - Cardinal Circle
 WATER SUPPLY: On-Site Well _____ Community _____ Public _____ EVALUATION BY: Auger Boring _____ Pit _____ Cut _____

| FACTORS | PROFILE 1 | PROFILE 2 | PROFILE 3 | PROFILE 4 | PROFILE 5 |
|---------------------------|-------------|-------------|-------------|-----------|-----------|
| LANDSCAPE POSITION | <u>L</u> | | | | |
| SLOPE (%) | <u>2.5%</u> | | | | |
| HORIZON I DEPTH | <u>48"</u> | | | | |
| Texture Group | <u>IS</u> | | | | |
| Consistence | <u>vfr</u> | <u>fine</u> | <u>fine</u> | | |
| Structure | | | | | |
| Mineralogy | <u>Si:1</u> | | | | |
| HORIZON II DEPTH | | | | | |
| Texture Group | | | | | |
| Consistence | | | | | |
| Structure | | | | | |
| Mineralogy | | | | | |
| HORIZON III DEPTH | | | | | |
| Texture Group | | | | | |
| Consistence | | | | | |
| Structure | | | | | |
| Mineralogy | | | | | |
| HORIZON IV DEPTH | | | | | |
| Texture Group | | | | | |
| Consistence | | | | | |
| Structure | | | | | |
| Mineralogy | | | | | |
| SOIL WETNESS | | | | | |
| FRICITIVE HORIZON | | | | | |
| ROLITE | | | | | |
| CLASSIFICATION | <u>S</u> | | | | |
| LONG-TERM ACCEPTANCE RATE | <u>.8</u> | | | | |


SOIL CLASSIFICATION: John S.H. SITE LONG-TERM ACCEPTANCE RATE: .8
 EVALUATED BY: _____ OTHER(S) PRESENT: None
 REMARKS: _____

LEGEND

| | | | | | |
|---|---|---|--|--|---|
| <p><u>LANDSCAPE POSITION</u></p> <p>Ridge Shoulder slope Linear slope Foot slope Nose slope Head slope Concave slope Convex slope Terrace Flood Plain</p> | <p><u>TEXTURE</u></p> <p>s - sand ls - loamy sand sl - sandy loam l - loam si - silt sil - silt loam scl - silty clay loam cl - clay loam scl - sandy clay loam sc - sandy clay sic - silty clay c - clay</p> | <p><u>MOIST</u></p> <p>vfr - very friable fr - friable fi - firm vfi - very firm efi - extremely firm</p> | <p><u>CONSISTENCE</u></p> <p>WET</p> <p>Ns - non-sticky Ss - slightly sticky S - sticky Vs - very sticky</p> <p>Np - non-plastic Sp - slightly plastic P - plastic Vp - very plastic</p> | <p><u>STRUCTURE</u></p> <p>sg - single grain m - massive cr - crumb gr - granular sbk - subangular blocky abk - angular blocky pl - platy pr - prismatic</p> | <p><u>MINERALOGY</u></p> <p>1:1, 2:1, mixed</p> |
|---|---|---|--|--|---|

The above standard abbreviations

NOTES:
 Soil Depth -- in inches
 Depth of Fill -- in inches from land surface
 Frictional Horizon -- thickness and inches from land surface
 Classification -- S (suitable), PS (provisionally suitable) or U (unsuitable)
 Long-Term Acceptance Rate -- gal/day/ft²



MOORE COUNTY HEALTH DEPARTMENT ENVIRONMENTAL HEALTH SECTION

P. O. BOX 279, Carthage, N. C. 28327
Phone: 947-2858

IMPROVEMENT PERMIT

Property Identification # 94-B

Owner Paul & Alice Parry

Address 50 Pines Phone No. _____

Exact Directions to Property Lot 94-B Cardinal Circle Wiggins Pines

Lot Area _____ Maximum Long-Term Acceptance Rate 8
(From Site Evaluation)

Daily Design Sewage Flow Rate (From Application) 360

Septic Tank Capacity 1000 gal Pump NO

Distribution Box yes Pump Tank Capacity _____


Depth of Gravel 12" Maximum-Trench Depth 36"

Dimensions of Nitrification Lines 2(85'x3')

Type of Water Supply public If Well, What Type _____

Distance To: Water Supplies _____ Lakes, Streams, Etc. _____

Easement Obtained (If Necessary) N/A Repair Area Required No



Comments/Conditions: loamy sand - 4 1/2"

Permit Issued By: [Signature] Date: 7-14-92

Approved By: _____ Date: _____

This Permit Expires 60 Months From Date of Issuance and is Subject to Revocation if Site Plans or the intended use of the Property Changes.

White Copy (Owner's Copy) Pink Copy (Electrical Inspector) Hard Copy (Office)