

Permit: 416427

www.arhs-nc.org

PIN:




Pasquotank

Owner:
 CAVALLERO, DANIEL R
 9590 BAY POINT DRIVE
 NORFOLK, VA 23518

Applicant:
 WALTON, TIM
 1049 HONEYCUTT WAY
 VIRGINIA BEACH, VA 23464

LTAR: 0.300
 Water: PUBLIC
 TYPE III G.
 MOBILE HOME
 GPD: 360

Location:
 419 SHADNECK ROAD



Fill 45' x 115' septic area 18 inches above current grade.
 Install tank shallow so that top of lines are no more than 6 inches below top of fill.
 Excavate 4 trenches 100' long, 3' wide, on 9' centers, and 5' deep.
 Backfill with sand to proper depth and install 12 inches of gravel and pipe or equivalent.
 Grade and landscape for proper surface drainage away from system.

Authorized Agent:



 Nixon, Wesley

Date: 08/20/2024

Approved:



Date: 10-18-24

ALBEMARLE REGIONAL HEALTH SERVICES
Final Inspection

Name: CAVALLERO, DANIEL R

Permit #: 416427

System Installer: DAVID PARKS

Manufacturer: NRM

Septic Tank Serial: 830

Gallons: 1,000


Drain Field Type: GRAVEL/TRENCH

Distribution Type: GRAVITY - PARALLEL (eq. d-box)

Number of Nitrification Lines: 4

Total Trench Length: 100

Comments:



EHS: 

Date: 10/18/2024

Nixon, Wesley