

New Hanover County Health Department  
Environmental Health Services  
230 Market Place Dr, Suite 140  
Wilmington, NC 28403  
(910) 798-6667 (910) 798-7269 fax

REPAIR PERMIT

### Authorization for Wastewater System Construction

Any Change to Proposed Use Or Site Plan Will Void Permit  
Permit Expires Five Years From Date Of Issuance

Owner/Applicant: VANESSA HEWETT SNAPSNECE  
Address: 314 GOLDEN ROAD  
WILMINGTON NC 28409

Phone No.: 378-6425 (DORRINE HAZ HEWETT)  
Site Location: 314 GOLDEN ROAD  
WILMINGTON NC 28409

Tax Parcel: R07915-005-011-000  
Subdivision: \_\_\_\_\_

Lot: \_\_\_\_\_ Block: \_\_\_\_\_ Section: \_\_\_\_\_  
Lot Dimensions: \_\_\_\_\_

Residential Commercial (circle one) If commercial, type: \_\_\_\_\_ gal/day 260  
No. Units: 1 No. Bedrooms: 3 No. Occupants/Employees: 6 max.  
Septic Tank Size: 1000 gallons Pump Tank Size: 1000 gallons LTAR: 4 gal/day/sq. feet (EXISTING SEPTIC TANK + PUMP TANK)  
System Type: 1/a Water Supply: \_\_\_\_\_ public X private (well permit required)  
No. Drainlines: 4 Length each: 45 FT Width each: 1.5 FT Drainfield Sq. Feet: 900 900  
Bed Dimensions: \_\_\_\_\_ FT x \_\_\_\_\_ FT Trench Bottom Depth: 12 inches (Max.)

Wastewater system must be installed to meet all requirements according to 15A NCAC 18A. 1900 *Laws and Rules for Sewage Treatment and Disposal Systems* (including)

- Keep system 50 feet minimum from all water supplies
- Keep system 10 feet from property lines.
- Keep system 10 feet from all water lines (includes irrigation systems)
- Do not drive over septic system area
- If septic system uses rock aggregate, install approved filter fabric

Site Plan

1. SEE SITE PLAN FOR SYSTEM LOCATION.  
2. INSTALL 4 @ 45FT LPP LATERALS UTILIZING THE 5FT SPACING BETWEEN ORIGINAL LINES.  
\* LPP LATERALS NEED TO BE SLEEVED IN 4" CORRUGATED PIPE  
\* RECHECK FLOAT SETTINGS AND ADJUST IF NECESSARY  
3. CONTRACT WITH A CERTIFIED OPERATOR NEEDS TO BE OBTAINED AND PROVIDED TO THE ENVIRONMENTAL HEALTH SECTION OF THE NEW HANOVER COUNTY HEALTH DEPT.

Construction Authorization issued by: Michael Burch R.S Date 2-14-05  
Permit not valid unless signed by Authorized Agent

Owner/Applicant: \_\_\_\_\_ Date: \_\_\_\_\_

**Operations Permit:** The above permitted wastewater system has been installed and found to meet the requirements for wastewater system installations as described in 15A NCAC 18A.1900 *Laws and Rules for Sewage Treatment and Disposal Systems*. This approval shall in no way be taken as a guarantee for the performance of the wastewater system for any given period of time.

System Installed by: \_\_\_\_\_ Date: \_\_\_\_\_

Operations Permit issued by: \_\_\_\_\_ Date \_\_\_\_\_  
Permit not valid unless signed by Authorized Agent

Final Approval Release: \_\_\_\_\_ Date \_\_\_\_\_

White copy- Env.Health      Pink copy- Building Inspections      Yellow copy- Owner      Green copy-System Installer