

PENDER COUNTY HEALTH DEPARTMENT
ENVIRONMENTAL HEALTH SECTION
P.O. Box 1209, Burgaw, NC 28425
Telephone 910/259-1233

EXISTING SEWAGE DISPOSAL SYSTEM AUTHORIZATION

ISSUED TO: April + Charles Watson FILE NO. 511933
ADDRESS: 124 Hunter Ct. CITY: Rocky Pt PHONE: / 270-1360
SUBDIVISION: Woodcliff STREET: Hunter Ct ST. NC ZIP 28457
MOBILE HOME PARK: _____ LOT: _____
DIRECTIONS TO PROPERTY: Hwy 210 W to Hollyshelter Rd turn Rt into Woodcliff Est. go to lot on Rt

STRUCTURE TYPE: MOBILE HOME [] HOUSE [] COMMERCIAL [] OTHER Deck

ORIGINAL SYSTEM OWNER: lund DATE INSTALLED lund
ORIGINAL SYSTEM RECORD: TANK: exist GAL; DRAINFIELD: exist SQ. FT.

At the time of inspection no visible signs of malfunction were evident. However, since this is a subsurface sewage disposal system, it is impossible for this office to determine if any unauthorized modifications or misuse has occurred.
No warranty or guarantee is implied or expressed and future performance of this system is not assured by the Pender County Health Department.
Failing to maintain a properly operating septic tank system is considered a public health hazard and a violation of North Carolina State Laws and Rules Governing Sanitary Sewage Collection, Treatment and Disposal (Article 11 N.C. General Statutes Chapter 130A). Should the system malfunction or fail in the future, it shall be the responsibility of the owner to apply for an Improvement Permit for the repair of the system.

PERMIT ISSUED FOR: 0 BEDROOMS; OTHER Deck

DWELLING SHALL BE LOCATED A MINIMUM OF FIVE (5) FT. FROM ANY PART OF SEPTIC SYSTEM AND REPAIR AREA.

REMARKS: _____

PERMIT VALID FOR SIX (6) MONTHS FROM DATE OF ISSUANCE.

SIGNED: [Signature] TITLE: RS DATE: 4-6-99

PCHD/EH4 REV. FEB. 94

White Copy, Applicant; Yellow Copy, Bldg. Inspection; Pink Copy, Office File.

S 58° 15' 46" W 336.09' TOT.

150.00'

0.38 AC (28)

S 28° 45' 21" E

150.00'

0.38 AC (30)

S 28° 53' 51" E

149.82'

0.37 AC (32)

S 14° 44' 14"

R.O.H.

0.46 AC (27)

25' EASEMENT

S 58° 15' 46" W

R.O.H.

140.46'

12.5'

10.00'

46" E 332.53' TOT.

40.00'

146.09'

150.00'

10.00'

40.00'

15' 46" E 327.16' TOT.

6'

10.00'

Hunter Court

28' x 56' DUMP

11' x 14' PITCH

15' 46" E 321.80' TOT.

40.00'

10.00'

N 14° 44' 14"

135.00'

0.44 AC (31)

S 58° 15' 46" W

40.00'

1" = 40'

(15)

PENDER COUNTY HEALTH DEPARTMENT
ENVIRONMENTAL HEALTH SECTION
P.O. Box 1209, Burgaw, NC 28425
Telephone 910/259-1233

EXISTING SEWAGE DISPOSAL SYSTEM AUTHORIZATION

ISSUED TO: CHARLES R. WATSON JR. FILE NO. 505523
ADDRESS: 124 HUNTER CT. CITY: ROCKY POINT ST. N.C. PHONE 1270-4072 ZIP 28457
SUBDIVISION: WOODCLIFF STREET: HUNTER CT. LOT: 29 BLK: _____
MOBILE HOME PARK: _____ LOT: _____
DIRECTIONS TO PROPERTY: SR 1002 - WOODCLIFF S/D - LOT ON Rt.

STRUCTURE TYPE: MOBILE HOME HOUSE COMMERCIAL OTHER _____

ORIGINAL SYSTEM OWNER: ACREAGE BROKERS DATE INSTALLED 7/12/88
ORIGINAL SYSTEM RECORD: TANK: 900 GAL; DRAINFIELD: 600 SQ. FT.

At the time of inspection no visible signs of malfunction were evident. However, since this is a subsurface sewage disposal system, it is impossible for this office to determine if any unauthorized modifications or misuse has occurred.
No warranty or guarantee is implied or expressed and future performance of this system is not assured by the Pender County Health Department.
Failing to maintain a properly operating septic tank system is considered a public health hazard and a violation of North Carolina State Laws and Rules Governing Sanitary Sewage Collection, Treatment and Disposal (Article 11 N.C. General Statutes Chapter 130A). Should the system malfunction or fail in the future, it shall be the responsibility of the owner to apply for an Improvement Permit for the repair of the system.

PERMIT ISSUED FOR: 3 BEDROOMS; OTHER _____

DWELLING SHALL BE LOCATED A MINIMUM OF FIVE (5) FT. FROM ANY PART OF SEPTIC SYSTEM AND REPAIR AREA.

REMARKS: ORIGINAL PERMIT # 4941110

PERMIT VALID FOR SIX (6) MONTHS FROM DATE OF ISSUANCE.

SIGNED: [Signature] TITLE: R.S. DATE 10/26/95
PCHD/EH4 REV. FEB. 94

PENDER COUNTY HEALTH DEPARTMENT

P. O. BOX 1200 BURGAW, N. C. 28425

(SEPTIC TANK)

CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System - G.S. Chapter 130 - Article 13C)

OWNER OR CONTRACTOR Acceage Brokers DATE 6-16-88 PERMIT NO. 494140

LOCATION 210 - 1001

SUBDIVISION NAME Wood Cliff LOT NO. 29 SECTION OR BLOCK NO. 1002

HOUSE MOBILE HOME BUSINESS
 NUMBER OF BEDROOMS 3
 GARBAGE DISPOSAL UNIT YES NO
 AUTO. DISHWASHER YES NO
 AUTO. WASH. MACHINE YES NO
 SITE SUITABLE YES NO
 SIZE OF TANK 900 GAL
 NITRIFICATION FIELD 600 SQ. FT.
 NUMBER OF LINES 3 lines at 67'
 IMPROVEMENTS PERMIT BY Pamela C Overstreet

LOT AREA 45 acres
 REMARKS 18" French bottoms 100
from all wells 10' from Property
line 5' from foundations

INSTALLED BY _____

CERTIFICATE OF COMPLETION BY Pamela C Overstreet DATE 7-12-88

Construction must comply with all other applicable State and local regulations.
This permit does not constitute a warranty or guarantee and is void after 36 months.

