

ONSLOW COUNTY HEALTH CENTER

JACKSONVILLE, N. C.

CERTIFICATE OF COMPLETION

(GROUND ABSORPTION SEWAGE DISPOSAL SYSTEM—G. S. CHAPTER 130 ARTICLE 13C)

OWNER Quail Point

Location _____ S.R. No. _____

Approved As Shown on Plot Plan ()

Approved As Shown on Final Plot ()

Lot 70 Blk _____ Sec III

Distance of Well: From Tank _____

From Drainfield _____

Have Tank and Drain Lines Inspected by a representative of the Onslow County Health Center before covering.

Installed By James Keenan

Certificate of Completion by R. Melville

Date 14/2/83

*THIS DOES NOT CONSTITUTE A WARRANTY OR GUARANTEE

ONSLOW COUNTY HEALTH CENTER

JACKSONVILLE, N. C.

IMPROVEMENTS PERMIT

(GROUND ABSORPTION SEWAGE DISPOSAL SYSTEM—G. S. CHAPTER 130 ARTICLE 13C)

OWNER Wendell S. Palgett

Address Lot # 70 S.R. No. _____

Location Quail Point Part III

Water Supply Private () Community () Mobile Home Park ()

HOUSE () MOBILE HOME () BUSINESS ()

NO. BEDROOMS 3 NO. BATHROOMS _____

Suitable () Prov. Suitable () Unsuitable ()

Locate Tank and Lines _____

Min. 100 Feet () Min. 50 Feet () From Well

Size of Septic Tank 1000 Gal.

Nitrification Lines 150 sq. Ft. 150 lin. Ft.

No. of lines _____

IMPROVEMENTS PERMIT BY R. Melville

DATE 23 June 83


PERMIT VALID FOR THREE YEARS

FINAL PLOT

Note French Bottoms

PLOT PLAN

No deeper than 18"



Do Not Alter the Above Layout Without Contacting The Onslow County Health Department