

ONSLow COUNTY
HEALTH DEPT.

ZHOP2014-00771
OPERATIONS PERMIT
(GS 130A-337)

Permit N^o 2825
System Type: III ✓

Owner: W. H. Burrus S/D
Address: Lot # 2 Tract 18
Location: Hwy 53 ~ 1/4 mile south of William Gurganus Rd. on left
SR # _____

FINAL PLOT/REMARKS
INSTALLED AS SHOWN ON PLOT PLAN
3 2 BEDROOM RESIDENCES
KSF

THIS DOES NOT CONSTITUTE A
WARRANTY OR GUARANTEE.

Installed By: RONNIE KELLUM
Signed By: Maren Furey RS
Date: 6-26-97

ONSLow COUNTY
HEALTH DEPT.

CONSTRUCTION AUTHORIZATION
(GS 130A-336)

Permit N^o 2825

THIS AUTHORIZATION FOR WASTEWATER SYSTEM CONSTRUCTION SHALL
BE VALID FOR A PERIOD EQUAL TO THE PERIOD OF VALIDITY OF
THE IMPROVEMENT PERMIT, NOT TO EXCEED 5 YEARS.

Owner: W. H. Burrus S/D
Address: Lot # 2 Tract 18
Location: Hwy 53 ~ 1/4 mile south of William Gurganus Rd. of left
SR # _____

System type/description: Polystyrene Aggregate Trench LTAR 0.6 gpd/sq. ft.
Septic tank size: ≥ 1500 gallons
Nitrification area: 900 sq. ft. 300 lin. ft.
No. of lines: 4 Line lengths: Each line 75'
Trench bottom depth: No Deeper Than 18"

(SEE ATTACHED PAGES 1 of 1 FOR ADDITIONAL PERMIT CONDITIONS)

Signed: Jon C. Harrison Date: June 19, 1997

ONSLow COUNTY
HEALTH DEPT.

IMPROVEMENT PERMIT
(GS 130A-336)

Permit N^o 2825

- Valid for 5 years from date of issuance
- Valid without expiration

Fee: \$ 70.⁰⁰

Owner: W. H. Burrus S/D
Address: Lot # 2 Tract 18
Location: Hwy 53 ~ 1/4 mile south of William Gurganus Rd. of left
SR # _____

System type/description: Polystyrene Aggregate Trench LTAR 0.6 gpd/sq. ft.
Facility/Daily design flow: 3 single family residences of no more than 2 bedrooms 4/or 4 occupant each. Waste water flow shall not exceed 240 gpd per dwelling
Water supply: On-site well Comm. well _____ Public _____ Other unit or 720 gpd total
(SEE ATTACHED PAGES 1 of 1 FOR ADDITIONAL PERMIT CONDITIONS)

Signed: Jon C. Harrison Date: June 19, 1997

NOTE: Permit is subject to revocation if site plans or intended use change.

ORIGINAL