

OPERATION PERMIT

Ground Absorption Sewage Disposal System
NC General Statutes Chapter 130A-Article 11

New Existing _____ Repair _____

Owner Bontatz Danny
Last First Middle

Location Eaglechase lot # 11

Type Use: Residence house # Bedrooms 4
Other _____

System Type: ITA Review Freq. N/A

Tank Cap. 1000 Mfgt. S+W Serial # 787

Sq. Ft. 990 # Lines 3 Width 36" Cover 12"

Pump Tank Cap. _____ Mfgt. _____ Serial # _____

Grease Trap Cap. _____ Mfgt. _____ Serial # _____


Other _____ Pump _____

Drainage Req'd. _____ Completed _____ H₂O Supply E. Pines

Comments _____

Installed by Stallings

Inspected by Bryan C. Harris R.S.



Stallings
1130

Re: 17969-02

12/16/1998
10:11:53

PITT COUNTY PUBLIC HEALTH CENTER
ENVIRONMENTAL HEALTH DIVISION
1717 W. 5TH STREET
GREENVILLE, N.C. 27834-1696
PHONE 413-1253

PAID
X YES
NO

EXISTING
NEW X SSE
REPAIR

APPLICATION

ARTICLE 11 OF CHAPTER 130A OF THE GENERAL STATUTES OF NORTH CAROLINA

DATE RECEIVED: 12/16/1998

APPLICATION NUMBER: 11952-98
PARCEL NUMBER: ~~49431~~ 53924

OWNER: DANNY GONZALEZ
ADDRESS: 3359 FORTERTOWN RD
GREENVILLE, NC 27858

IDENTIFIER #: 21299-0011

PHONE: HOME 252-756-8424 WORK 919-714-8760

LOT NO: 11
BLOCK NO:

DIRECTIONS: SR 1726

RE: 38-92 (NEED CHANGE OF FLOW PERMIT) - increasing bedrooms from original permit

LAND USE: HOUSE
WATER SUPPLY: EASTERN PINES
BEDROOMS: 004 OCCUPANTS: 000
SIZE OF LOT/DIMENSIONS: SEE MAP

[Signature]
OWNER/APPLICANT'S SIGNATURE

TANK SIZE 1000 IMPROVEMENT PERMIT
NITRIFI. 990 ft² ROCK WITHIN See below INCHES SYSTEM TYPE Ifc
FLOOD PLAIN _____ PLOT PLAN REQ'D yes ESTIMATED FLOW 480
DATE OF EVAL. 1-4-99


REMARKS:
System area is very specific: Trenches shall not be placed within drainage requirements. Rainfield shall be at least 10' off shoulder of driveway Northern property line.
Trenches shall begin with top of rock 12" below EXISTING ground surface.
DO NOT BUILD, DRIVE OR PARK OVER SYSTEM OR REPAIR AREA.

AN AUTHORIZATION TO CONSTRUCT A WASTEWATER SYSTEM MUST BE OBTAINED FROM ENVIRONMENTAL HEALTH BEFORE CONSTRUCTION OF THE WASTEWATER SYSTEM BEGINS.

DATE ISSUED 1-27-99 ENVIR. SPECIALIST Nancy Deal

DATE APPROVED 6-22-99 ENVIR. SPECIALIST Bryan C. Harris P.S.
IMPROVEMENT PERMIT SUBJECT TO REVOCATION IF SITE PLAN OR INTENDED USE CHANGE


IMPROVEMENT PERMIT VALID (X) NO EXPIRATION
() 5 (FIVE) YEARS



EAGLECHASE LANE

60' R/W - 20' ASPHALT

AUTHORIZATION TO CONSTRUCT
 BY Nancy A. Corey
 DATE 1-27-99
 PERMIT # 11952-98
 Valid for Five (5) Years
 OR Expiration Date of Permit



PARCEL NO. _____ DRAWN BY BLW

REFERENCE:
 MAP BK. 43, PG. 102

CERTIFICATION
 I, GARY S. MILLER, CERTIFY THAT THIS PLAT WAS DRAWN UNDER MY SUPERVISION FROM INFORMATION AS RECORDED IN MAP

MAP FOR
DANNY GONZALEZ

LOT 11
 EAGLECHASE SUBDIVISION