

# PAMLICO COUNTY HEALTH DEPARTMENT



P.O. BOX 306  
BAYBORO, N.C. 28515

## IMPROVEMENT PERMIT (valid 5 years)

Owner: Weyerhaeuser Real Estate DC  
Owner Address: 1412 Eatonton Hwy. Suite 700  
Owner Address(2): Madison, GA 30650  
Owner Phone #: (252) 637-4702  
Property Address: 45 North Halls Creek Road  
Property Address(2): Lee Landing S/D  
PIN: C05-7-2  
Record # 51609-2  
Establishment Type: Home  
Type of Well: Public Well  
Design Flow (GPD): 360

Initial Site  
Wastewater System: Conventional Pipe  
Long Term Acceptance Rate (GPD/SQFT): 0.8  
Trench Width: 3 FT  
Trench Spacing (OC): 9 FT  
Trench Bottom From NGL: -20 IN  
Septic Tank Volume: 1000 GAL  
Place soil cloth over rock

Repair Site  
Wastewater System: Conventional Pipe  
Long Term Acceptance Rate (GPD/SQFT): 0.8  
Trench Width: 3 FT  
Trench Spacing (OC): 9 FT  
Trench Bottom From NGL: -20 IN  
Septic Tank Volume: 1000 GAL



**AN AUTHORIZATION TO CONSTRUCT MUST BE OBTAINED AND ALL FEES PAID PRIOR TO WASTEWATER SYSTEM INSTALLATION.**

**THE PAMLICO CO. HEALTH DEPARTMENT RESERVES THE RIGHT TO REVOKE THIS PERMIT IF THE SITE IS ALTERED, INTENDED USE CHANGED, OR ANY INFORMATION IS FALSIFIED.**

**ANY CHANGES TO THIS PERMIT WILL REQUIRE A REDESIGN PERMIT AND SUBSEQUENT FEE.**

Authorized Agent: Bryan C. Harris RS Date 3/29/2007  
#1524