

IMPROVEMENT PERMIT (Valid for 60 months from date of issue) (Building permit cannot be issued unless CA is marked)

CONSTRUCTION AUTHORIZATION (Expires with Improvement Permit on: 4/25/2027)

This authorization is for a/n _____ to a wastewater system.

Applicant/Owner: **Mitchell West** PIN#: **551403009581000** Zone: **MP** Acreage: **1.29**

Property Description: **River Bend At Valley River Lot 9 and 10**

Facility: **Residential, 3 bedrooms** Maximum # Occupants: **6** Basement: **No**

Design Flow: **360 gpd** Water Supply: **Existing Shared Well (off-site)**

IMPROVEMENT PERMIT

CONSTRUCTION AUTHORIZATION

System: 25% Red. - Gravity Class: IIIg
Soil Depth: 58" Saprolite: 0 LTAR: 0.5 Slope: 17%
Repair: 25% Red. - Class: IIIg
Repair Soil Depth: 52" LTAR: 0.5

Septic Tank: 1000 gal Pump Tank: Not Req'd
Trench Length: 180' & Spacing: 9' Min (On Center)
Trench Depth: 18" Max (Low Side) & Width: 36" Max
Distribution: Serial

Permit Conditions:

Do not disturb designated system areas. Divert all drainage from system areas. Maintain all setbacks. Do not bench
Installer is responsible for installing lines level and on contour.

Diagram (Not to Scale)

- Install per LSS report attached, Permit number 2007001190 Lot 9. 10/22/07

This permit/authorization is subject to revocation if the information submitted in the application is found to have been incorrect, falsified or changed, the site is altered, or intended use changes; is transferable; and is subject to the provisions of the Laws and Rules for Sewage System Collection, Treatment, and Disposal of the North Carolina Administrative Code. (By signing this document, I accept the specifications of this permit)

Date: 5/3/22

Issue Date: 4/25/22

Malachi Beaver, REHSI 2870

Malachi Beaver Owner/Legal Reps. Signature
Malachi Beaver REHSI Authorized State Agent