




Terrill & Sandy Robinson

IMPROVEMENT PERMIT

Currituck County

Owner: Terrill & Sandy Robinson  
Owner Address: 9158 Ciri Lake Lane Fort Belvor Va. 22060  
Owner Phone #: 703-781-0695  
Property Address: Lot 194 Sec. 4A Carolina Club Dr.  
PIN: 33240  
Record # 094G-000-0194-0000  
Establishment Type: Home  
Type of Well: Public  
Design Flow (GPD): 480  
178 Carolina Club Dr.

Initial Site  
Wastewater System: Disposal Bed  
Long Term Acceptance Rate (GPD/SQFT): 0.5  
Trench Width: 3 FT  
Trench Spacing (OC): 3 FT  
Trench Bottom From NGL: -18 IN  
Septic Tank Volume: 1000 GAL



\*\*Set tank very high so that top of lines are 6 inches below original grade.  
\*\*Keep system 50'+ from any well  
\*\*(24' x 60' Bed System) 8 lines, 60' long, 3' on-center

Authorized Agent: Kevin Carver Date 8/29/2005

Approved: [Signature] Date: 5/24/06