



CARTERET COUNTY HEALTH DEPARTMENT

Environmental Health Division
3820 Bridges Street, Suite A, Morehead City NC 28557

Existing System #: 8214
Operation Permit #: N/A

SATISFACTORY EXISTING SYSTEM AUTHORIZATION TO CONNECT

*No authorization to construct shall be issued until all modifications have been completed and approved by this office.

OWNER: RUSSELL GASKILL
ADDRESS: 424 LOLA RD
CEDAR ISLAND, NC 28520
PHONE #: (252) 342-4091

APPLICANT: RYAN HRYNISZAK
ADDRESS: 2689 CEDAR ISLAND RD
CEDAR ISLAND, NC 28520
PHONE #:

PARCEL ID: 841503138942000
PROPERTY LOCATION: 424 LOLA RD Carteret County CEDAR ISLAND, NC 28520 Subdivision CEDAR ISLAND BAY ESTATES, Lot 8

PURPOSE OF REQUEST: MH connection

DESIGN FLOW: 240 *gpd*
SYSTEM CLASSIFICATION:
WATER SUPPLY: Private Well

FACILITY TYPE: Single Family
BEDROOMS: 2
OCCUPANTS: 4

Septic tank: existing (gal)
Dosing tank: _____ (gal)
lines: 2
Length of lines: 70 (ft)

Bed width: 0 (ft)
Bed length: 0 (ft)

Comments: Absolutely no vehicular traffic over any part of the wastewater system.

Operation Permit shall be valid as long as the sanitary sewage system is in compliance with Article 11 of G.S. Chapter 130A Law and Rules for Sewage Treatment and Disposal Systems (15 NCAC 18A.1900) of all conditions of this permit including the items specified below.


1. The sewage collection, treatment and disposal system shall be operated and maintained at all times to prevent public health hazards, to prevent seepage or discharge of sewage effluent to the surface of the ground or surface waters, and to prevent direct discharge of effluent to the ground water.
2. In the event the system fails, a repair must be permitted and installed within 30 days.
3. This permit does not constitute a warranty and does not negate or supersede any zoning restriction or restricted covenants the chain of title. It is the responsibility of the permittee to determine whether or not such restrictions apply.
4. This permit is transferable and is valid only with respect to the facilities described herein and the specified design flow. Prior to any expansions or revisions a revised permit shall be obtained from the Carteret County Health Department.
5. Septic tank sludge accumulation shall be evaluated every three (3) years and pumped when sludge level is found to be 12" or greater in depth.
6. Structure shall be placed so that gravity flow is achieved or a pump system shall be required.
7. Do not park, pave, drive or build over any part of the septic system or repair area.
8. Maintain a minimum of five (5) feet between any foundation and any part of the septic system and repair area.

Existing System #: 8214

Operation Permit #: N/A

The Carteret County Health Department reserves the right to make inspections of these sewage collection treatment and disposal facilities as necessary to assure compliance with the provisions of this permit and the North Carolina Laws and Rules for Sewage Treatment and Disposal systems.

SITE PLAN



Amber Hill REH
Environmental Health Specialist

01/12/2016

Date