

Nash County Environmental Health
 On-Site Wastewater Permit
 120 W. Washington Street, Nashville, NC 27856
 252-459-9829



Permit Number: E-24-1023

Parcel ID: 356713

TOWNSHIP: Castalia

PIN: 287400211200

Owner: Tim Matthews

Applicant: Tim Matthews

Company: East Coast Timberland, Inc.

Subdivision: Culpepper Landing

Sect: Ph: Lot: Phase One, Lot 19

Address of Property: 7094 RACE TRACK RD CASTALIA, NC 27816

Design Specifications: New Subsurface Disposal System Non-Residential Use:

Design Flow: 360

LTAR: 25

Trench Length: 360' X 3'

Size Tank: 1000

Pump Tank:

Grease Trap:

Type System: 25% Reduction

Max Trench Depth: 18"

Bedrooms: 3

Max Occupants: 6

Additional Inspections Required: Chamber

Installer: Tyler

This permit is valid for 5 years from Improvement Permit date.

Conditions: Do not drive, park, build, pave or concrete over any part of the system or repair. Site alterations or variations from the site plan may void permit and/or make the site unsuitable. System must be installed as permitted. Install drain lines on contour. Install drain field in dry conditions. If a pump system is required, a pressure manifold shall be used. This permit is written for a three bedroom home with six resident maximum. Install four 90' X 3' PA or C lines on 9' centers. Lines run behind the house. No benchmark was used on this property. Shape cover to shed surface water. Original system area has been flagged. Do not remove flags. It is highly recommended to pump out you septic tank once every 3 to 5 years for maintenance. Call the Environmental Health with any further questions.

Improvement Permit: **August 22, 2024**

Construction Authorization: **February 6, 2025**

Operation Permit: 3-13-25

Authorized State Agent (Digitally Signed By): **Eric Griffin REHS**

Authorized State Agent (Digitally Signed By): **Eric Griffin REHS**

Authorized State Agent (Digitally Signed By): ELW

*M-115-1000
 575-858-24
 12-13-24*

PS 1 of 2

