

3100

ETOP2012-01841

ONSWLOW COUNTY
HEALTH DEPT.

OPERATIONS PERMIT
(GS 130A-337)

Permit **Nº 7308**
System Type: **III** ✓

Owner: Swansboro Landing S/O
Address: **Property Address:** 111 HIDDEN CREEK DR
Location: Blue Crab Ct.

FINAL PLOT/REMARKS
(1) 3BR residence - 360 gpd

SR # —
THIS DOES NOT CONSTITUTE A WARRANTY OR GUARANTEE.
Installed By: Randy Arnold
Signed By: Butzille
Date: 3-1-01

ONSWLOW COUNTY
HEALTH DEPT.

CONSTRUCTION AUTHORIZATION
(GS 130A-336)

Permit **Nº 7308**

THIS AUTHORIZATION FOR WASTEWATER SYSTEM CONSTRUCTION SHALL BE VALID FOR A PERIOD EQUAL TO THE PERIOD OF VALIDITY OF THE IMPROVEMENT PERMIT, NOT TO EXCEED 5 YEARS.

Fee: —

Owner: Swansboro Landing S/O
Address: Lot 27
Location: Blue Crab Ct.

System type/description: Polystyrene Aggregate LTAR .3 gpd/sq. ft.
Septic tank size: 2900 gallons
Nitrification area: 1200 sq. ft. 300 lin. ft.
No. of lines: 4 Line length: 75' each line
Trench bottom depth: 24" at deepest point
(SEE ATTACHED PAGES 1 - 1 of 1 FOR ADDITIONAL PERMIT CONDITIONS)

Signed: MEC, RS. Date: 1-28-99

ONSWLOW COUNTY
HEALTH DEPT.

IMPROVEMENT PERMIT
(GS 130A-336)

Permit **Nº 7308**

- Valid for 5 years from date of issuance
- Valid without expiration

Fee: \$100.00

Owner: Swansboro Landing S/O
Address: Lot 27
Location: Blue Crab Ct.

System type/description: Polystyrene Aggregate LTAR .3 gpd/sq. ft.
Facility/Daily design flow: 360 gpd for (1) 3BR residence
Water supply: On-site well Comm. well Public Other
(SEE ATTACHED PAGES 1 - 1 of 1 FOR ADDITIONAL PERMIT CONDITIONS)

Signed: MEC, RS. Date: 1-28-99

NOTE: Permit is subject to revocation if site plans or intended use change.

ORIGINAL

PLOT PLAN

Additional Permit Conditions:

Owner: Swansboro Landing #10
 Address: Lot 27
 Location: Blue Crab Ct.

1. Do not park or drive on any part of system or repair area.
2. Nitrification trench aggregate shall be covered with straw, untreated paper or other approved materials prior to final cover/backfilling.
3. Do not install system under wet conditions.
4. Adhere to minimum set back requirements as stated in Rule .1950 and .1951 of NC Laws and Rules for Sewage Treatment and Disposal System. (Article 11, G.S. Chapter 130A). Unless otherwise indicated in this permit.
5. Rock used in soil absorption systems shall be clean, washed gravel or crushed stone and graded or size in accordance with size numbers 3,4,5,57, or 6 of ASTM D-448 (standard sizes of coarse aggregate) which is hereby adopted by reference in accordance with G.S. 150 B-14 (c). Documentation of aggregate size shall be available upon request.
6. All pump tanks shall be tested for water tightness. Septic tanks may be subject to a water tightness test.
7. House location shall accommodate system and meet all required setbacks.
8. Install trenches on contour. Lay out system with a transit prior to installing.

scale 1" = 50'

