Pasquotank-Perquimans-Camden-Chowan District Health Department

REFERENCE NUMBER:	DATE:	PARCEL IDENTIFIER:	COUNTY:
Alternative 17639 IMPROVEMENT	11/03/99	0055, 0014A	PERQUIMANS

REQUESTEE:	OWNER:
SAWYER, DEANNA RT 4 BOX 745 HERTFORD, NC 27944 TELEPHONE: 264-5127	SAWYER, DEANNA RT 4 BOX 745 HERTFORD, NC 27944 264-5127

LOCATION/DIRECTIONS:
DEEP CREEK ROAD GO ALL THE WAY TO THE END WHERE ROAD ENDS

HIT DIRT ROAD AND THE LOT IS ON THE LEFT. 679 Deep Creek Rd

FEE:	WATER:	SEWER:	REMARKS:
150.00 Bill 24820	PUBLIC PRIVATE		

PERMIT SHALL BE VALID FOR 60 MONTHS FROM DATE OF ISSUE.

This permit is NOT to be used for installation unless accompanied by a valid Authorization for Wastewater System Construction.

# Bedrms 3	Disposal 0	# People 3	Type Bld R
Size Tank 1000	Line Len 100	# lines 4	Width Bot 3
Backfill 4.00 ft			

PERMIT IS SUBJECT TO REVOCATION IF SITE PLANS OR THE INTENDED USE CHANGES.



Conditions for Installation:

- Install a 1000 gallon septic tank and one distribution box
- Install 4 lines 100 feet long, 3 feet wide and on 10 foot centers
- Excavate trenches to at least 4 feet and backfill with sand
- Keep the system at least:
  - 5 feet from building foundations
  - 10 feet from property lines
  - 10 feet from public water lines
- Landscape for proper surface drainage

PASQUOTANK-PERQUIMANS-CAMDEN-CHOWAN DISTRICT HEALTH DEPARTMENT COPY

Date Issued: 11/29/99 Sanitarian: JONATHAN R MORGAN

Date Approved 1-6-00 Signature Jonathan R Morgan RS
Operation Permit