

**BRUNSWICK COUNTY HEALTH DEPARTMENT**

DATE REC.: 2/9/2006

P.I.N.:

FILE NO.: 2006067156

ZONING: 2006057887

HOLMES H L

340.00

214CI076

REC. FROM

AMT. PD.

TAX PARCEL

P O BOX 1216

SHALLOTTE

NC

28459-

(910) 443-8916

ADDRESS

CITY

ST

ZIP

PHONE

HOLMES DEVELOPMENT & REALT

RUTLEDGE

76

PH-1

CURRENT PROPERTY OWNER

SUBDIVISION

LOT

BLK

SEC

PROPERTY LOCATED, TOWN/CITY/AREA BRUNSWICK COUNTY

DIRECTIONS TO PROPERTY HWY 17S TO HOLDEN BEACH RD TO GRAY BRIDGE RD TO TARLANDING RD TO RUTL

3298 Kensington Square SW 28470

**AUTHORIZATION FOR WASTEWATER CONSTRUCTION PERMIT**

NEW  REVISION  RELOCATION  UPGRADE  REPAIR

Design Flow: 360 gpd. Septic Tank Size: 900 gal. Type: III B

No. Bedrooms 3 No. occupants/employees 6 Max. Trench/Bed Bottom Depth: 18-24 inches

No. Lines: 4 Length Each: 23 Bed Dimensions: N/A

Fill Check: \_\_\_\_\_ Date \_\_\_\_\_ Approved: \_\_\_\_\_ Authorized Agent \_\_\_\_\_


- NOTES:**
1. Septic Tank shall have an approved effluent filter and access devices as applicable.
  2. Maintain all setback distances for septic tank systems and wells.
  3. All components of the septic systems shall be located 100 feet if possible but not less than 50 feet to all existing and future wells on this parcel and adjacent parcels.

PERMIT ISSUE DATE: 3/1/06 Permit expires 60 months from date of issue unless otherwise specified

30 days from date of issue  Other \_\_\_\_\_

Authorized Agent Travis Hewett Registration: 2081

NOTES: PERMIT IS SUBJECT TO REVOCATION IF SITE PLANS OR THE INTENDED USE CHANGES.  
IMPROVEMENT PERMIT CONDITIONS MUST BE MET.



1. System design using 25% reduction with Infiltrator Systems, AWW5-05-01
2. Install c-box @ highest point.
3. Tank may need back filling to maintain gravity flow.
4. Call 253-2363 if you have questions.

Wastewater System Installer: Terry White

Date: 8/30/06

Comments: (tank info/barrier approved) CC2S-900 STR-375 7/19/06

OPERATION PERMIT: Travis Hewett

Date: 8/30/06

Authorized Agent Signature

Actions of local health department representatives or the State engaged in the evaluation and determination of measures required to effect compliance with the applicable laws and rules shall in no way be taken as a warranty that sewage treatment and disposal systems approved and permitted will function in a satisfactory manner for any given period of time. The issuance of this permit does not preclude the Permittee from complying with any and all statutes, rules and regulations or ordinances which may be imposed by other government agencies (local state, and federal) which have jurisdiction.