

CERTIFICATE OF COMPLETION

GROUND ABSORPTION SEWAGE DISPOSAL SYSTEM - G.S. CHAPTER 136A ARTICLE 111

OWNER Braun, Kenneth

Location S.R. #

Approved As Shown on Plot Plan

Approved As Shown on Final Plot

Bay Shores Est. Lot 14 Blk Sec
Distance of Well: From Tank
From Drainfield

Keep Tank and Drain Lines Inspected by a representative of the Pamlico County Health Department before covering

Installed By: J. Miller

Certificate of Completion By: D. Spangour

Date: 4/25/87

THIS DOES NOT CONSTITUTE A WARRANTY OR GUARANTEE

IMPROVEMENTS PERMIT # 1341

(GROUND ABSORPTION SEWAGE DISPOSAL SYSTEM - G.S. CHAPTER 136A)

OWNERS: Braun, Kenneth

Address: Hwy 55 from Barbours, left on SR 1324. Approx 4 miles on left (Bay Shores) lot Cul de sac (Cul-de-sac)

Water Supply: Private Public Mobile Home

HOUSE MOBILE HOME BUSINESS

NO. BEDROOMS 3 NO. BATHROOMS 2

Suitable () Prov. Suitable

Locate Tank and Lines feet from well: 100ft.

Size of Septic Tank: 900 gallons

Nitrification Lines: 450 square feet

3(50) No. of Lines 150 lin. feet

Comments: nitrification trench bottoms re deeper than 18 inches stay 100ft from water with any point of Septic system Place well 100ft from any site of Septic system


IMPROVEMENTS PERMIT BY: Bruce Withrow

Date: 12-28-84

PERMIT VALID FOR THREE YEARS

FINAL PLOT

PLOT PLAN



Do Not Alter the Above Layout Without Contacting The Pamlico County Health Department

APPLICATION FOR LOT INSPECTION

DATE: 11-26-84

APPLICANT: Raymond E. Drennon PHONE: 633-5320

MAILING ADDRESS: P.O. 1389 New Bern 28560

SUB DIVISION: LOT NO. 14 BLOCK/SECTION HWY #

LOCATION: Bay Shore Estates, #1389, SR 1324, Approx 1/2 mile

turn left, approx 1/2 mile on right. Cul-de-sac

TYPE OF DWELLING: house NO. BEDROOMS: 3? NO. BATHS: 2? WASHER: DISHWASHER:

WATER SUPPLY: PUBLIC () PRIVATE (X) LOT SIZE:

EXISTING SYSTEM:

COMMENTS:

SIGNATURE OF APPLICANT

ACTION TAKEN

PERMIT ISSUED:

APPLICATION DENIED:

COMMENTS:

SIGNATURE OF SANITARIAN

RIVER

