



at

\*File #: 311506 - 2  
 PIN #: 733803209641000  
 Tax Lot #:  
 Tax Block #:

**WELL CONSTRUCTION RECORD** *Certificate of Completion*

Owner: Joseph Behan  
 265 Otway Farm Rd  
 Beaufort, NC 28516

Directions

**WELL HEAD CONSTRUCTION**

Location: *265 Otway Farm Rd, Beaufort, NC 28516*  
 Latitude:  
 Longitude:

- Enclosure  Yes  No  N/A
  - Enclosure Floor  Yes  No  N/A
  - Access Port  Yes  No  N/A
  - Vent:  Yes  No  N/A
  - Sample Tap  Yes  No  N/A
  - Back Flow  Yes  No  N/A
  - Tee (jet)  Yes  No  N/A
  - Suction Line  Yes  No  N/A
  - Temporary  Yes  No  N/A
  - Well ID Plate  Yes  No  N/A
  - Pump ID Plate  Yes  No  N/A
- EHS: Tovsky, Andrew

Issue Date: 12/15/2021

Drilling Contractor: Cyclone Well Drilling  
 Driller Registration: 3416-A  
 Date Drilled: 12/09/2021  
 Use of Well: SINGLE FAMILY

Total Depth: 130 Ft.  
 Static Water Level: 5 Ft.  
 Replacement Well: YES  
 Yield: 30 gpm

Water Zone: 1) 118 Ft. 2) Ft.  
 3) Ft. 4) Ft.  
 Disinfection Type: GRANULAR Amount: 2oz

**Casing:** Depth: 118 Ft. Thickness: in. Comments:  
 Diameter: 2 In. Top of Casing: 12 In.  
 Material: PVC SCH 40

**Grout:**

From	To	Depth	Material	Method
From 0	To 20	Ft.	BENTONITE	POUR
From 0	To	Ft.	N/A	N/A

\* Liner Date: From 0 To Ft.

**Grout:**

From	To	Depth	Material	Method
From 0	To	Ft.	N/A	N/A

Issued by: Tovsky, Andrew

Date of Issue: 12/15/2021



CDP File Number: 311506

County File Number: 733203209641000


Date: 09/30/2021

Drawing Type:

1" = 40'

- Well shall maintain following setbacks:
  - ↳ 25' to any existing or proposed structure or foundation
  - ↳ 50' to any part of wastewater system area

Existing well shall be abandoned in accordance with "ISA NCAC 02C.013- Abandonment of Wells"



- AT 12/6/21
- Cyclores
  - 2" PVC
  - poured 20' (2 bags)
  - chlorinated

Otway Farm Rd