




IMPROVEMENT PERMIT

Pasquotank County

Owner: Kar San
Owner Address: 1151 Hwy 17 South
Owner Address(2): Elizabeth City, NC
Owner Phone #:
Property Address: Lot 123 Queenswood
Property Address(2): 102 Maidens Court
PIN: 33290
Record # 8901881799
Establishment Type: Home
Type of Well: Public
Design Flow (GPD):

Initial Site
Wastewater System: Alternative
Long Term Acceptance Rate (GPD/SQFT)
Trench Width: 3 FT
Trench Spacing (OC): 10 FT
Trench Bottom From NGL: -18 IN
Septic Tank Volume: 1000 GAL



Install tank shallow so that top of lines are no more than 6 inches below grade. Excavate 5 trenches 80' long, 3' wide, on 10' centers, and 5.5' deep. Backfill with 4' of sand and install 12 inches of gravel and pipe. Keep system at least 10' from all property and water lines, and 5' from any structure. Grade and landscape to promote proper runoff of surface water away from system.

Authorized Agent: [Signature] Date 9/1/2005

Approved: Kelly Russell, R.S. Date: 11/15/05

Septic Tank Installation Checklist

Name Kar Sam

Permit# 33290

Septic System Contractor Stevenson

Septic Tank Serial # STB-S30

Gallons 1000 Date of Manufacture —

Sanitary Tee filtered

Approved Pipe from Tank to Nitrification Lines

Baffle

Distribution Box Outlets Level Speed Leveler

Nitrification Lines

	1	2	3	4	5	6	7	8
Grade	/	/	/	/	/	/	/	/
Length	/	/	/	/	/	/	/	/
Width	/	/	/	/	/	/	/	/
Rock	/	/	/	/	/	/	/	/
Pipe	/	/	/	/	/	/	/	/
Depth from surface	/	/	/	/	/	/	/	/

Modifications

Shallow placement _____

Drainage _____

Grease Trap _____

Other _____

Changes in Layout

(5) 100 ft lines installed

Date 11/15/05 Environmental Health Specialist

Kelly Russell, R.S.