

GA



Well Construction Permit

Carteret County Health Department
Environmental Health Division
3820 Bridges St. Suite A
Morehead City NC, 28557
Phone: 252-728-8499 Fax: 252-222-7753

For Office Use Only			
*CDP File Number:	<u>224409</u>		
PIN Number:	<u>64950060679800</u>		
Tax Lot #:	<u>25</u>	Tax Block #:	<u>1A</u>
Evaluated For:	<u>SINGLE FAMILY WELL</u>		

Property Owner: Henry McRee
 Address: 2792 Pallmer Drive NE
 City: Conover
 State/Zip: NC / 28613
 Phone #: C: (828) 244-0858

Applicant: John Maguire
 Address: ~~2727 Myrtle St~~ 320 channel Rock Rd
 City: ~~Morehead City~~ Beaufort
 State/Zip: ~~NC / 28557~~ 28516
 Phone #: ~~C: (252) 773-0574~~ 631 413-3182

Property Location & Site Information

Address/Road #: 129 GARBACON DR
BEAUFORT NC, 28516
 Subdivision: MERRIMON BAY
 Phase: _____ Lot: 25
 *Proposed use of Well: SINGLE FAMILY
 Directions _____ If Other: _____

Well Contractor Information

Drilling Contractor: _____ Driller Registration: _____

Permit Conditions

*Permit Conditions
 * Well shall meet the following minimum setbacks:
 - 50' from any part of any septic system and repair area
 - 25' from any building perimeter, including attached structures
 - 25' from surface water bodies, such as creeks, streams, rivers, sounds, bays and tidal estuaries

Well location, construction and protection must meet all state and local regulations and must be inspected and approved by an authorized representative of the Local Health Department. The permit may be revoked at any time for failure to comply with existing regulations. The siting of approved well construction area(s) by the Health Department is to provide protection from the known possible sources of contamination. The approved well area(s) may not be changed without permission from an authorized representative of the Local Health Department. No volume of quality of water is guaranteed by the Health Department.

*Issued By: Chris, Barfield
 Authorized State Agent: *Chris Barfield*
 Owner/Applicant: _____

*Date of Issue: 11/29/2021
 Hand Drawing Import Drawing
 Site Plan/Drawing attached.

WELL CONSTRUCTION PERMIT



CDP File Number: 224409

County File Number: 649500606798

Date: 11/29/2021

Drawing Type:

*Well shall meet the following minimum setbacks:

- 50' from any part of any septic system + repair area
- 25' from any building perimeter, including attached structures
- 25' from surface water bodies, such as creeks, streams, rivers, sounds, bays + tidal estuaries.



