

**Environmental Health Section
Beaufort County Health Department
220 N. Market St.
Washington, North Carolina 27889
(252) 946-6048**

New Construction
 Repair


No. R- 8260

Date: 4/29/03

OPERATION PERMIT

This permit guarantees only materials used and method of installation and that it meets all state regulations for new constructions.

Owner: Terry Hasey Phone: _____
 Address: _____ Lot Number: _____
 State Road Number: _____ Type Structure: House
 Septic Tank I.D. _____ Pump Tank I.D. _____
 Installer: Mike Smith 10-DIGIT PIN 6645-12-0143
 Additional for all systems: Landscape system area for surface water runoff and grass.
 Do not place drive or any building over the system area or repair area.



Remarks: _____
 Environmental Health Specialist: Dee Woodard, e.s. Date: 4/29/03

White Owner/Contractor Yellow - Health Department Pink Building Inspections

**Environmental Health Section
Beaufort County Health Department
220 N. Market St.
Washington, North Carolina 27889
(252) 946-6048 / Fax (252) 946-2074**

New Construction
 Repair


Dee Woodard, e.s.
4/21/03
R-8260

IMPROVEMENTS PERMIT

Improvements permits are subject to revocation if the site plans or intended use changes or site alterations occur.

NOT TO SCALE

Date: 4/21/03
 Owner: Terry D. Hasey Phone: _____
 Address: 13066 U.S. 264 E Pinetown, N.C.
 Subdivision: _____ Lot Number: _____
 State Road Number: _____ Directions East on (264 E)
 10-DIGIT PIN 6645-12-0143
 Property Size: _____ Type Structure: House
 No. Bedrooms: 3 No. People: 4
 Water Supply: Community (Maintain minimum _____ feet separation from any part of septic system and repair area.)
 Classification: Suitable Provisionally Suitable PS with fill
 Additional Drainage: _____
 Seasonal Wetness Condition: _____ Soil Type: _____
 Septic Tank: 1000 gal. Pump Tank: _____ gal.
 Nitrification Field: 1020 square feet trench bottom
 Trench Depth: 18" Fill Depth: _____
 Comments: Set new tank as shallow as existing plumbing will allow. Crush old tank. Destroy well - Add 4 lines for repair.



Additional for all systems: Landscape system area for surface water runoff and grass. Do not place drive or any building over the system area or repair area. Observe all proper setbacks (10 NCAC 10A .1950). Do not work soil or install system in wet conditions. This permit must be on site during installation and inspection.

Environmental Health Specialist: Dee Woodard, e.s. Date: 4/21/03

White Owner/Contractor Yellow - Health Department Pink Building Inspections