

**HARDEN'S PEST CONTROL**

**PO BOX 2153**

**ELIZABETH CITY NC 27906**

**Service Proposal**

**(252)333-9753**

137 Howells Ln. Hertford, NC 27944

\* Water marks on piers & walls in crawl; Pipe not connected; Need crawldoor on right side; Tack Up Insulation; Mildew on wooden members; 22% Moisture Content; Need gutters to keep water away;

① Install Sand in Crawlspace; - \$ 2,650.<sup>00</sup>  
- remove moisture Barrier

② Tack Up Insulation - \$ 150.<sup>00</sup>

③ Mildew Treatment - \$ 800.<sup>00</sup>

④ Install Crawlspace Door - \$ 350.<sup>00</sup>  
- 16x32 on right side

Total - \$ 3,950.<sup>00</sup>

SIGN: \_\_\_\_\_ DATE: \_\_\_\_\_

COMPANY REP: Charles Hill DATE: 9-15-2025