

**ENVIRONMENTAL HEALTH DIVISION
CARTERET COUNTY HEALTH DEPARTMENT**

2855

CERTIFICATE OF COMPLETION: (Ground Absorption Sewage Disposal System - G.S. 130A - 337) 3/24/92
 OWNER: Elmer J. Lewis West Haven, Lot 14, P#3
 INSTALLER Wayne See DATE COMPLETED: 12-1-92

Notice: This certification of completion in no way binds the Environmental Health Division of Carteret County Health Department nor implies a guarantee that this system will function in all circumstances, but that the system is properly installed in accordance with applicable rules and regulations of the Carteret County Health Department and can reasonably be expected to perform properly under normal conditions of use and maintenance.

set house at least 5' from septic tank and at least 31' from front property line

By: [Signature]

G.S. 130A-336
 IMPROVEMENT PERMIT
 VALID FOR 60 MONTHS


**ENVIRONMENTAL HEALTH DIVISION
CARTERET COUNTY HEALTH DEPARTMENT
BEAUFORT, N.C. 28516**

2855

Subject to revocation if site plans, elevations or intended use is altered.

PHONE 726-9711/6346 DATE 3/24/92

OWNER: Elmer J. Lewis
 ADDRESS: Wayne Dr - Bldg 1A - Morehead City
 PROPERTY LOCATION: West Haven
Lot 14, Phase 3, Tr#13-155-1-12
 TYPE STRUCTURE: House
 NO. BEDROOMS: 3 NO. BATHS: 2
 WATER SOURCE: Ind Well
 GARBAGE GRINDER YES () NO ()
 SIZE OF TANK: 1000 Gal.
 SIZE OF PUMP TANK: 1000 if Needed Gal.
 NO. LINES: 4 WIDTH: 14"
 TOTAL: 560 SQ. FT.
 TOTAL LENGTH: 40' FT.
 HORIZONTAL DISTANCE FROM WELL: 100' FT.



NOTICE: Construction must comply with all state and local regulations. Do not install well until well site has been approved. Do not cover any portion of system until approved on final inspection.

Notice: Beware, much property in Carteret County is subject to Wetland Regulations and properties containing wetlands should receive approval from U.S. Army Corps of Engineers prior to development.

IMPROVEMENTS PERMIT BY: [Signature]
 Agent

PLOT PLAN



CARTERET COUNTY COURTHOUSE

ENVIRONMENTAL HEALTH DIVISION
CARTERET COUNTY

COURTHOUSE SQUARE
BEAUFORT, N. C. 28516

NOTIFICATION OF SITE EVALUATION

DATE: 30 March 1992

NAME: Elmer J. Lewis & Son

ADDRESS: Wayne Drive - Building 1A
Morehead City, NC 28557

PHONE: 726-9711

PROPERTY LOCATION: Lot 14, Phase 3
West Haven Subdivision

TAX PARCEL: 13-15S-1-12

INSPECTED BY: David W. Adcock, Jr., R.S. *DA*
Environmental Health Specialist

You are hereby informed that the site as described above has been evaluated by this office and found to meet the permitting requirements.

An Improvements Permit is available for an additional \$20.00 fee. You will need to contact this office within six (6) months to pick up the permit or an additional evaluation and/or fee may be required.

If you have any further questions please feel free to contact this office at (919) 728-8499.

CW

4-2-92 pd for permit CW