WILSON COUNTY HEALTH DEPARTMENT
Environmental Health Section
1801 Glendale Drive, SW
Wilson, NC 27893-4401
252-291-0468

☐New ☐Revised
☒Repair ☐Successive

Permit: 2013-094
File: 2793-32-8902

IMPROVEMENT PERMIT

Owner: Ernest & Edna Woodruff, III Phone: 252-230-4086
Address: 5410 Lamm Road, Wilson, NC 27896-
Directions: 264 W, TR on 1001 TO property located @ 5410 Lamm Rd left

Facility: Existing House #Bedrooms: 3 Drainfield Ft2: 900 Pump Tank: 1000 gal Other: ____
Starting Trench Depth: 24" Septic Tank: 1000* gal Water Supply: Private Distance to Well: 100' Design Flow: 360 gpd

COMMENTS

This permit written for repair of the existing system. It is recommended to check all fixtures in home for leaks. The existing septic tank may be used if in good condition and has a baffle wall. Sanitary T and filter shall be added if it does not exist. Otherwise a new 1,000 gallon septic tank will be required. It is recommended septic tank and pump chamber be pumped, crushed, and filled. This permit requires the use of an approved pumping system (septic tank, pump tank, manifold). See the following page for specifications on wiring, alarm, etc. Contractor shall be aware of existing utilities. Install four 75' X 3' conventional lines on 9' centers or greater centers.

* Please See Continuation of Comments on Following Page*

SITE SKETCH MAP

OTHER REQUIREMENTS AND INFORMATION ON REVERSE
The wastewater system and other improvements shall be installed as shown, **except that if this permit is written for the installation of a conventional system, an accepted system may be installed instead.** AN IMPROVEMENT PERMIT IS SUBJECT TO REVOCATION IF SITE PLAN, PLAT, OR INTENDED USE CHANGES. The use of a garbage disposal is not recommended. This permit expires ☒60 months from issue date or ☐NO Expiration)

10-24-2013 William R Mosley Jr REHS
Issue Date Environmental Health Specialist

CONSTRUCTION AUTHORIZATION FOR IMPROVEMENT PERMIT# 2013-094

Unless otherwise indicated, the same conditions above apply regarding system type, layout, location & installation requirements. (The wastewater system cannot be installed until authorization is signed).

Comments:
Date: 10-24-2013 Environmental Health Specialist: William R Mosley Jr REHS

OPERATION PERMIT

Comments: ORP1000 STB628 9-10-13 MCP-1000 PTS3 5-16-13 3-75' E2 Flow ok ABC
Pressure head, cover ok, Electrical, pump, alarm ok 11-6-2013

Environmental Health Specialist: William R Mosley Jr REHS
Date: 11-6-2013 Installed By: Dale Pridgen

WM/sjp