

TO:		WORK PERFORMED AT:	
Tom Norville		107 INNISBROOK CT.	
678 Trent Farm Lane		New Bern NC 28562	
New Bern NC 28562		One Day code	
DATE	YOUR WORK ORDER NO.	OUR BID NO.	
7/26/23	Steve Little Tom Norville		

DESCRIPTION OF WORK PERFORMED	
HVAC Inspection - Bryant Logo - split system Heat Pump w/ City of New Bern Load MGT.	
Outdoor unit m/n 225BNA030-A 2.5 ton MFG Date March 2012	
S/N 0912E23218 R410A refrigerant	
Indoor unit m/n FX4DNF031 2.5 ton MFG Date April 2012	
S/N 1712AB2189 TXV, 10 KW Aux Heat	
USES pump for condensate removal (requires yearly service)	
shows signs of previous condensate removal issues	
All ductwork seems to be sealed and intact	
Refrigerant pressures & motor amps within MFG specs.	
Equipment in good working condition @ this time.	
1 - HVAC Inspection / Evaluation	Cost \$150.00
	NC sales tax (6.75%) + 10.13
	<u>Total Due \$160.13</u>
Michael G. Parks	
State Lic # 14126	
PARKS NEW BERN	
THANK YOU	

All Material is guaranteed to be as specified, and the above work was performed in accordance with the drawings and specifications provided for the above work and was completed in a substantial workmanlike manner for the agreed sum of _____ Dollars (\$ _____).

This is a Partial Full invoice due and payable by: _____ Month _____ Day _____ Year
 in accordance with our Agreement Proposal No. _____ Dated _____ Month _____ Day _____ Year