

Permit: 464294

PIN: 8920195116



Pasquotank

Owner:
Steve W Meads
PO BOX 1303
Elizabeth City, NC 27909


Applicant:
Cardom LLC
156 N Currituck Rd
Moyock, NC 27958

LTAR: 0.300
Water: PUBLIC
TYPE V F.
SINGLE FAMILY
GPD: 480

Location:
615 Meadstown Rd

*****MUST BE INSTALLED BY
PROPERLY CERTIFIED SEPTIC
CONTRACTOR*****

*****KEEP 25 FEET FROM ANY
LARGE DRAINAGE DITCHES*****



**Install tank so that top of lines are no more than 6 inches below current grade.
Excavate 5 trenches 100' long, 3' wide, on 9' centers, and 4.5' deep.
Backfill with sand to proper depth and install 12 inches of gravel & pipe or equivalent.
Grade septic area for proper surface drainage.**

Authorized Agent: 
Nixon, Wesley

Date: 02/09/2026

Approved: _____

Date: _____

THE AUTHORIZATION FOR WASTEWATER SYSTEM CONSTRUCTION (CONSTRUCTION AUTHORIZATION) SHALL BE VALID FOR A PERIOD OF 60 MONTHS AFTER THE DATE OF ISSUANCE.

The issuance of the Improvement Permit or Construction Authorization in no way guarantees the issuance of other local, state or federal permits.

Wastewater systems and water supplies shall meet state and/or local regulations.

NO CHANGES IN THIS DOCUMENT ARE ALLOWED UNLESS PRIOR APPROVAL IS OBTAINED FROM THE HEALTH DEPARTMENT. IF THE INFORMATION SUBMITTED IN THE APPLICATION FOR THE IMPROVEMENT PERMIT OR CONSTRUCTION AUTHORIZATION IS FOUND TO BE INCORRECT, CHANGED, OR IF THE SITE IS ALTERED, THE IMPROVEMENT PERMIT OR CONSTRUCTION AUTHORIZATION SHALL BECOME INVALID AND MAY BE SUSPENDED OR REVOKED.

When contacting the Environmental Health office concerning this document, be sure to know the application number. The number must be used in all inquiries and inspection requests.

The Environmental Health Staff can be located at the following telephone numbers between 8:00 a.m. and 8:30 a.m., Monday through Friday, except holidays. The office telephone numbers are:

Camden.....	(252) 338-4460	Pasquotank.....	(252) 338-4490
Chowan.....	(252) 482-1199	Perquimans.....	(252) 426-2100
Currituck.....	(252) 232-6603	Bertie.....	(252) 794-5303
Hertford.....	(252) 862-4054	Gates.....	(252) 357-1380

Wastewater system installers are responsible for notifying the Environmental Health offices for final inspections. Wastewater systems must be inspected and approved by a representative of the Environmental Health staff before any portion of the installation is covered and/or used.

ISSUANCE OF AN OPERATIONS PERMIT SHALL INDICATE THE WASTEWATER SYSTEM HAS BEEN CONSTRUCTED TO THE STANDARDS SET FORTH IN THE REGULATIONS, BUT SHALL IN NO WAY BE TAKEN AS A GUARANTEE THAT THE SYSTEM WILL FUNCTION SATISFACTORILY FOR ANY GIVEN PERIOD OF TIME.

Wastewater systems shall be operated and maintained in such a manner as to not create a public health hazard. Septic tanks should be pumped out every 3 to 5 years by a permitted pumper. Please conserve water!

Minimum Distances*

Ground Absorption Wastewater Systems to:

1. Private water supply sources 100'
2. Public water supply sources 100'
3. Coastal waters (mean high water mark) 50'
4. Streams, canals, marshes, or other surface waters 50'
5. Lakes and ponds 50'
6. Groundwater lowering ditches and devices 25'
7. Embankments or cuts 15'
8. Swimming pools 15'
9. Property Lines 10'
10. Water lines 10'
11. Building foundations 5'

Private Wells to:

1. Wastewater systems 100'
2. Building foundations 25'
3. Surface waters 50'
4. Property lines 10'

*Variances can be given on some distances; please call the Environmental Health office if you feel a variance is necessary.

Septic tanks, nitrification fields, and repair areas shall not be located under paved areas or areas subject to vehicular traffic.