



Harry & Helen Wilson  
Geo. Hoffman Cons.


IMPROVEMENT PERMIT

Currituck County

Owner: Harry & Helen Wilson  
Owner Address: 415 Grasmere Dr.  
Owner Address(2): Aberdeen, MD 21001  
Owner Phone #: 410-575-7909  
Property Address: Lot 103 Carolina Club  
Property Address(2): 101 Charleston Dr.  
PIN: 25925  
Record # 094G-000-0103-0000  
Establishment Type: Home  
Type of Well: Public  
Design Flow (GPD): 480

Initial Site  
Wastewater System: Conventional Pipe  
Long Term Acceptance Rate (GPD/SQFT): 0.5  
Trench Width: 3 FT  
Trench Spacing (OC): 9 FT  
Trench Bottom From NGL: -18 IN  
Septic Tank Volume: 1000 GAL

\*\*Place system at least 10' from public water lines or property lines, 15' from any ditches or dropoffs, 5' from any structure, 100' from any well.  
\*\* 4 lines, 80' long, 3' wide, 9' on-center  
\*\* Set tank very high so that top of lines are 6" below original grade.



INSTALLER: TNT

\*\* Conserve Water!! Use 1.6 Gallon Commodes.  
\*\* Grade and Landscape septic area to promote runoff of rainwater.

Authorized Agent: Kevin Carver Date 4/22/2003

Approved: Ronnie Coyle RB Date: 11-25-03