

02.1269.28



Wayne County (Environmental) – Repair Permit

301 N. Herman Street, Box CC, Goldsboro, NC 27530

Phone:(919) 731-1174

Fax:

Permit No: 12080104363

Appl. Dt.: 9/6/2012

Exp. Dt.: 9/6/2017

Status: ISSUED

Status Dt.: 9/20/2012

Owner Information

Name : Robert Morgan
 Address : 6004 Meadow Lane
 Goldsboro NC 27530
 Phone(W) :
 Phone(H) :
 Phone(M) :

Property Information

PIN # : 022577998544
 Address : 6004 Meadow Ln
 Goldsboro NC 27530
 Acreage : 0
 Subdivision : Lt 28 Hillsdale
 Lot # :
 Directions :

Site Details

System Type : Type II
 System Description : Conventional septic sys (750
 linear feet of nitrification line
 or less)
 Line Length : 4(50x4)
 Line Depth : 36.00
 Nitrification Sq. Ft. : 800.00
 Tank #1 : Septic Tank - 1000.00
 Tank #2 :
 Tank #3 :

Applicant Information

Name : Robert Morgan
 Address : 6004 Meadow Lane
 Goldsboro NC 27530
 Phone(W) :
 Phone(H) :
 Phone(M) :

Occupant Information

Name : Robert Morgan

Water Details

System : New
 Source : Private

Property Characteristics

Type of establishment : Residential dwelling units
 Number of establishment : 4 Bedrooms
 Septic GPD : 480
 Basement : No
 Basement Bath : No
 Garbage Disposal : No
 Multiple Dwelling Units : No
 Property Notes :

Notes : Must re-route water line to be 10' from all parts of septic system. Crush and fill old tank. Install backfill barrier.

Inspections Conducted

Inspections	Signed Off/User ID	Date	Status	Reason
IP	EHJBLIZZ	9/10/2012	OK/S	
ATC	EHJBLIZZ	9/10/2012	OK/S	
OP	EHJBLIZZ	9/20/2012	OK/S	Block

Payment Information

Permit	Receipt No.	Fee	Ref#1	Amount	Status	Ref#2	Amount	Status	Ref#3	Amount	Status
MAINPERMIT	12080103752	0	CASH	0	PAID						
Total				0							

Installation Report

Property Information 6004 meadow Ln.
Hillsdale Ct 28

Tank Sizes

Septic Tank 1000 Pump Tank N/A

Effluent Filter ✓ Air Vent ✓

Nitrification Field

System Type II

Length of Trenches 48' 48' 48' 48' (x4')
#1 #2 #3 #4

Trench Depth 36"

Trench Centers 9'00"

Comments or Revisions:

I have inspected the septic system detailed above and find it to be installed in accordance to the North Carolina Sewage Laws and Rules.

ABH/d
Environmental Health Specialist

9.20.12
Date