

August 7, 2025

Ricky Simpson Plumbing LLC

212 Sarason Place

Vass, NC 28394

On 8/7/25 we went and checked out the polybutylene waterline piping at 6 Chalford Place in Pinehurst, N.C. Piping appears to be in good shape.

We recommend to change all stops at sinks and toilets. The piping should be fine.

If you have any questions give me a call at 910-690-3831.

Thanks,

A handwritten signature in black ink, appearing to read 'Ricky Simpson', with a large, sweeping flourish at the end.

Ricky Simpson

On 9/17/25 Ricky changed all stops at sinks and toilets.