

CERTIFICATE OF COMPLETION

(GROUND ABSORPTION SEWAGE
DISPOSAL SYSTEM—G.S.
CHAPTER 130A-335)

OWNER Riverwood Estates

Location Candlewood Dr. S.R. No. _____

Approved As Shown on Plot Plan

Approved As Shown on Final Plot

Lot 2 Blk G Sec _____

Distance of Well: From Tank _____
From Drainfield 9.5 ft

Have Tank and Drain Lines Inspected by a representative of the Onslow County Health Center before covering.

Installed By Leslie M. Ready

Certificate of Completion by U. H. St. Paul

Date 7-21-87

*THIS DOES NOT CONSTITUTE A WARRANTY OR GUARANTEE

IMPROVEMENTS PERMIT

(GROUND ABSORPTION SEWAGE DISPOSAL SYSTEM—
G. S. CHAPTER 130A-335)

OWNER Riverwood Estates

Address Candlewood Drive S.R. No. _____

Location lot 2G

County water (x)

Water Supply Private Community Mobile Home Park

HOUSE MOBILE HOME BUSINESS

NO. BEDROOMS 3 NO. BATHROOMS 2

Suitable Prov. Suitable Unsuitable

Locate Tank and Lines ten ft. from any water line

Min. 100 Feet Min. 50 Feet From Well

Size of Septic Tank 1000 Gal.

Nitrification Lines 450 sq. Ft. 150 lin. Ft.

No. of lines 3-50'

IMPROVEMENTS PERMIT BY Carey S. Houghton

DATE March 24, 1987

PERMIT VALID FOR THREE YEARS

FINAL PLOT

