Charles R. Fisher Construction Inc.

Charles Fisher, Owner
910-262-7861
PO Box 2502, Surf City, NC 28445

ONSITE WASTEWATER INSPECTION REPORT

No representation, warranties or opinions are hereby given, written or expressed otherwise, as to the future performance of onsite wastewater system described herein. This onsite wastewater system inspection is a presentation of system facts in place on date of inspection.

Address of Property 410 S. Anderson Blvd. Topsail Beach, NC 28445

Current Owner of Record D & L Rentals (Marty Ellis & Sharon Porterfield)

Inspection requested by: ✓ Owner of record ____ Other Name ____

Company Sellers

Phone 910-538-1854

Date of Inspection: 4/16/2021

N/A Copy of Operations Permit from ____ County Environmental Health Attached
✓ Operations permit not available
Type of water supply: ____ Well ✓ Public Water ____ Community Water
Location of Septic Tank and Septic Tank Details:

- 10 ft. from house or structure
- N/A ft. from well if applicable
- 30> ft. from water line if applicable
- 27 ft. from property line
- 14" approximate distance from surface to top of tank
- ____ Access riser(s) ___yes ✓ no Describe: ____
- ____ Tank lids intact ___yes ✓ no
- NO Tank has baffle wall ____yes ✓ no
- yes Inflow to tank is noted as sufficient
- N/A Inflow to tank is noted as insufficient or blocked
- NO Outlet has filter ____yes ✓ no
- yes Outlet T is present ✓ yes ____ no
- ____ Effluent leaves the outlet ✓ yes ____ no
- ____ Roots present in tank ____yes ✓ no
- ____ Evidence of infiltration into tank of surface water ____yes ✓ no
- NO Evidence of tank leakage noted
- N/A Unable to locate tank; System inspection cannot be completed until tank is located.

Date tank was last pumped: 4/16/2021

Percentage of sludge detected in tank 0 %