

PENDER COUNTY HEALTH DEPARTMENT
ENVIRONMENTAL HEALTH SECTION
P.O. Box 1209, Burgaw, NC 28425
Telephone 910/259-1233

EXISTING SEWAGE DISPOSAL SYSTEM AUTHORIZATION

FILE NO. 512069

ISSUED TO: ANTHONY MALASCHAK PHONE 910 / 259-1619

ADDRESS: 202 COPPERHEAD LN. CITY: BURGAU ST. NC ZIP 28425

SUBDIVISION: WINDY TAIL RIDGE STREET: _____ LOT: 9 BLK: _____

MOBILE HOME PARK: _____ LOT: _____

DIRECTIONS TO PROPERTY: HWY 53 EAST, RIGHT ON STAR PARK, STRAIGHT ON WHITESTOCKING RD. MAKE A LEFT ON COPPERHEAD LANE. PROPERTY LOCATED ON RIGHT SIDE OF ROAD.

STRUCTURE TYPE: MOBILE HOME HOUSE COMMERCIAL OTHER _____

ORIGINAL SYSTEM OWNER: CHARLES WELLS DATE INSTALLED 9-15-88

ORIGINAL SYSTEM RECORD: TANK: 900 GAL; DRAINFIELD: 400 SQ. FT.

At the time of inspection no visible signs of malfunction were evident. However, since this is a subsurface sewage disposal system, it is impossible for this office to determine if any unauthorized modifications or misuse has occurred.

No warranty or guarantee is implied or expressed and future performance of this system is not assured by the Pender County Health Department.

Failing to maintain a properly operating septic tank system is considered a public health hazard and a violation of North Carolina State Laws and Rules Governing Sanitary Sewage Collection, Treatment and Disposal (Article 11 N.C. General Statutes Chapter 130A). Should the system malfunction or fail in the future, it shall be the responsibility of the owner to apply for an Improvement Permit for the repair of the system.

PERMIT ISSUED FOR: 3 BEDROOMS; OTHER REPLACING A 14x56 WITH A 29x56 MODEL 14.0

DWELLING SHALL BE LOCATED A MINIMUM OF FIVE (5) FT. FROM ANY PART OF SEPTIC SYSTEM AND REPAIR AREA.

REMARKS: PERMIT IS ONLY ISSUED FOR A 3 BEDROOM DWELLING.

PERMIT VALID FOR SIX (6) MONTHS FROM DATE OF ISSUANCE.

SIGNED: [Signature] TITLE: EHS DATE 5-5-99
PCHD/EH4 REV. FEB. 94

PENDER COUNTY HEALTH DEPARTMENT
P.O. Box 1209, Burgaw, NC 28425
Telephone 919/259-1233

SEPTIC TANK IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
Article 11 N.C. General Statutes Chapter 130A
and
Pender County Rules and Regulations

Owner/Agent Charles Wells Date 9/15/88 Permit# 494730
Address Rt 2 Box 2777 Burgaw 28425
Location of Site SK 1411 - dirt - underneath Pender Co. Radiotower White Stocking Feed area
Subdivision White-tail Ridge Lot# 9 Section/Block —
House Mobile Home (# Bedrm) 3 Business (# Employees/Members/Seats) —
SEPTIC TANK SIZE 900 Gal. NITRIFICATION FIELD 400 Sq.Ft.
NUMBER OF LINES 2 LENGTH 67 Ft. DEPTH 18 In. BED SYSTEM SIZE —

LOCATION OF SYSTEM: See layout sketch or attached plot plan. NO CHANGE IN SEPTIC TANK SYSTEM OR ITS LOCATION WITHOUT PRIOR APPROVAL FROM PENDER COUNTY HEALTH DEPT.


N
O
T
E

MINIMUM HORIZONTAL SEPARATION OF SEPTIC SYSTEM TO NEAREST:
Well: 100 ft., Property Line: 10 ft., Foundation: 5 ft., Ditch or
Subsurface Tile: 25 ft. (10 ft if upslope).

SPECIAL INSTRUCTIONS OR REQUIREMENTS:

Install 6" suitable fill in area nitrification field. Install 18" trench bottoms from surface of fill. Keep system in back of lot as written.

LAYOUT SKETCH



This permit does not constitute a warranty or guarantee and satisfactory performance is not assured by the Pender County Health Department.

IMPROVEMENTS PERMIT BY: Sherril Lyon MPH PERMIT VALID 36 MONTHS

CERTIFICATE OF COMPLETION BY: Pamela Brunsted DATE: 9-15-88

Installed by: _____