

- IMPROVEMENT PERMIT** (Valid for 60 months from date of issue) (Building permit cannot be issued unless CA is marked)
- CONSTRUCTION AUTHORIZATION** (Expires with Improvement Permit on: **03/09/2016**)
- This authorization is for a/n _____ to a wastewater system.

Applicant/Owner: **Transcendent, LLC** PIN#: **540900643403000** Zone: **MP** Acreage: **0.94**

Property Description: **Overlook Brasstown Lot # 95**

Facility: **Residential, 2 bedrooms** Basement: **Yes with fixtures**

Design Flow: **240 gpd** Water Supply: **Existing Shared Well** (off-site)

IMPROVEMENT PERMIT

CONSTRUCTION AUTHORIZATION

System: LDP-10 - Gravity Class: IIIlf
 Soil Depth: 47" Saprillite: 0 LTAR: 0.5 Slope: 45%
 Repair: Drip - Pump NSF-40 Class: Vc
 Repair Soil Depth: 31" LTAR: 0.2

Septic Tank: 1000 gal Pump Tank: Not Req'd
 Trench Length: 200' & Spacing: 7.5' Min (On Center)
 Trench Depth: 18" Max (Low Side) & Width: 12" Max
 Distribution: Serial

Permit Conditions:

Do not disturb designated system areas. Divert all drainage from system areas. Maintain all setbacks. Do not bench. Installer is responsible for installing lines level and on contour.

Diagram (Not to Scale)

Install per LSS report attached submitted by HUFF ENVIRONMNETAL CONSULTING, INC. sealed by David Knox Huff on 02/24/2011.

House and Drive must be built to accommodate system and repair.

This permit/authorization is subject to revocation if the information submitted in the application is found to have been incorrect, falsified or changed, the site is altered, or intended use changes; is transferable; and is subject to the provisions of the Laws and Rules for Sewage System Collection, Treatment, and Disposal of the North Carolina Administrative Code. (By signing this document, I accept the specifications of this permit)

Date: 3-9-11 [Signature] Owner/Legal Reps. Signature

Issue Date: 03/09/2011 Trevor Peterson, REHS 2143 [Signature] REHS Authorized State Agent

