


CERTIFICATE OF COMPLETION

(GROUND ABSORPTION SEWAGE
DISPOSAL SYSTEM—G. S.
CHAPTER 130A-335)

OWNER LAKE VIEW ESTATES
235 Pineview SE
Location ~~1500 1/2~~ R. 111 S.R. No. 111
Approved As Shown on Plot Plan ()
Approved As Shown on Final Plot (✓)
Lot 4 Blk H Sec _____
Distance of Well: From Tank _____
From Drainfield 370
Have Tank and Drain Lines Inspected by a representative of the Onslow County Health Center before covering.
Installed By Rudolph Thomas
Certificate of Completion by LHA Stebbins
Date 4-18-90

*THIS DOES NOT CONSTITUTE A WARRANTY OR GUARANTEE




IMPROVEMENTS PERMIT

(GROUND ABSORPTION SEWAGE DISPOSAL SYSTEM—
G. S. CHAPTER 130A-335)

OWNER LAKE VIEW Estates ^{John} HARR
Address ~~1500 1/2~~ R. 111 S.R. No. 111
Location LOT 4 Blk H
ON AIRPORT Rd just before 1st entrance
Water Supply Private () Community (✓) Mobile Home Park ()
HOUSE () MOBILE HOME (✓) BUSINESS ()
NO. BEDROOMS 3 NO. BATHROOMS 2
Suitable () Prov. Suitable () Unsuitable ()
Locate Tank and Lines Existing
Min. 100 Feet () Min. 50 Feet () From Well
Size of Septic Tank 750 Gal.
Nitrification Lines 300 sq. Ft. 100 lin. Ft.
No. of lines 250
IMPROVEMENTS PERMIT BY LHA Stebbins
DATE 4-18-90

PERMIT VALID FOR THREE YEARS



51