

PENDER COUNTY HEALTH DEPARTMENT

P. O. BOX 1209 BURGAW, N. C. 28425

(SEPTIC TANK)

CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System - G.S. Chapter 130 - Article 13C)

OWNER OR CONTRACTOR B. J. Bryant II / HARNETT CONST CO DATE 11/22/87 PERMIT NO. 492013

LOCATION Kings Landing Road, Hamstead, N.C. SR 1565

SUBDIVISION NAME Seven Acres LOT NO. 7 SECTION OR BLOCK NO. 1565

HOUSE MOBILE HOME BUSINESS

NUMBER OF BEDROOMS 3

GARBAGE DISPOSAL UNIT YES NO

AUTO. DISHWASHER YES NO

AUTO. WASH. MACHINE YES NO

SITE SUITABLE YES NO

SIZE OF TANK 900 GAL

NITRIFICATION FIELD 300 SQ. FT.

NUMBER OF LINES 2 lines @ 50

IMPROVEMENTS PERMIT BY H. Lewis

LOT AREA 102 x 170

REMARKS 1 1/2" trenches, 100' ft from all
walls, 10' ft inside property line,
5' ft from foundation

INSTALLED BY Jacobs

CERTIFICATE OF COMPLETION BY [Signature] DATE 20 Oct 1988

Construction must comply with all other applicable State and local regulations. This permit does not constitute a warranty or guarantee and is void after 36 months.

